

COPIES TO
 - DIVISION OF WATER RESOURCES
 - CLIENT'S COPY
 - WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. **10230**
 Permit No. _____
 Basin **212**

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **30792**

1. OWNER **FONTAINEBLEAU LAS VEAS LLC** ADDRESS AT WELL LOCATION **2755 S LAS VEGA BLVD.**
 MAILING ADDRESS **2827 PARADISE RD** **LAS VEGAS, NV**

2. LOCATION **SE 1/4 NE 1/4 Sec 09 T 21 S R 61 E** **CLARK** County

PERMIT NO. **DW1233** **162-09-602-002** **Fontainebleau**
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE (**DEWATER**)
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
49-Dewater wells				
Depth 40'				
Brown dirt & rock		0	14'	14'
Moist dirt & rock	x	14'	17'	3'
White silty clay		17'	19'	2'
Brown silty clay		19'	32'	13'
Caliche		32'	34'	2'
Brown clay		34'	40'	6'

8. WELL CONSTRUCTION

Depth Drilled **40** Feet Depth Cased **40** Feet

HOLE DIAMETER (BIT SIZE)
 From **24** Inches To **0** Feet **40** Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
 Type perforation **Machine**
 Size perforation **1/4" x 2.5" long 16 around**

From **20** feet to **40** feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal _____ Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From **0** feet to **40** feet

**DCNR/DWR
 RECEIVED
 JAN 23 2007**

LAS VEGAS OFFICE

Date started **1/3, 20 07**
 Date completed **1/17, 20 07**

7. WELL TEST DATE

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

9. WATER LEVEL
 Static water level **15** feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **ALLEN DRILLING INC.**
 (CONTRACTOR)
 Address **4015 WEST TOMPKINS AVE**
 (CONTRACTOR)
LAS VEGAS, NV 89103
 Nevada contractor's license number issued by the State Contractor's Board **18916 & 18917**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **ABDS2161**

Signed *[Signature]*
 By driller performing actual drilling on site or contractor
 Date **January 18, 2007**