

COPIES TO  
 - DIVISION OF WATER RESOURCES  
 - CLIENT'S COPY  
 - WELL DRILLER'S COPY

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. **102275**  
 Permit No. **212**  
 Basin **212**

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **30791**

1. OWNER **KRYSTLE TOWERS LLC**  
 MAILING ADDRESS **2827 PARADISE RD LAS VEGAS, NV 89109**  
 ADDRESS AT WELL LOCATION **2845 S LAS VEGAS BLVD LAS VEGAS, NV**

2. LOCATION **SE 1/4 NE 1/4 Sec 09 T 21 S R 61 E CLARK County**  
 PERMIT NO. **DW1234 162-09-704-001** Fontainebleau  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE (DEWATER)  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<b>44 Dewater wells</b>				
<b>Depth 40'</b>				
Brown dirt & rock		0	14'	14'
Moist dirt & rock	x	14'	17'	3'
White silty clay		17'	19'	2'
Brown silty clay		19'	32'	13'
Caliche		32'	34'	2'
Brown clay		34'	40'	6'

8. WELL CONSTRUCTION  
 Depth Drilled **40** Feet Depth Cased **40** Feet  
 HOLE DIAMETER (BIT SIZE)  
 From **24** Inches To **0** Feet **40** Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:  
 Type perforation **Machine**  
 Size perforation **1/4"x2.5" long 16 around**  
 From **20** feet to **40** feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal \_\_\_\_\_  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From **0** feet to **40** feet

9. WATER LEVEL  
 Static water level **15** feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name **ALLEN DRILLING INC.**  
(CONTRACTOR)  
 Address **4015 WEST TOMPKINS AVE LAS VEGAS, NV 89103**  
(CONTRACTOR)  
 Nevada contractor's license number issued by the State Contractor's Board **18916 & 18917**  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **ABDS2161**  
 Signed *David J. [Signature]*  
 By driller performing actual drilling on site or contractor  
 Date **January 18, 2007**

Date started **12/14, 20 06**  
 Date completed **1/3, 20 07**

7. WELL TEST DATE

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

DCMR/DWR RECEIVED

JAN 23 2007

LAS VEGAS OFFICE