



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 30872

1. OWNER M. Holdings LLC 222 ADDRESS AT WELL LOCATION 12415 Gillespie
Via Marnell way St, Las Vegas NV
Las Vegas NV

2. LOCATION SE 1/4 NW 1/4 Sec 9 T. 23 N 61 E Clark County
 PERMIT NO. 191-09-201-021 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Pulled system from the well				
Abandoned 8" well to 550' Depth.				
Existing perforations from 550' to 400'				
Perforated casing from 400' to 270'				
Pumped in 7.5 yards of neat cement through a tremmie line from the bottom of the well to the surface. Which completely filled the well.				
DCNR/DWR RECEIVED				
PLUGGED BY GWMP				
ORIG. PLUG LOG # <u>53464</u>				
JAN 22 2007				
LAS VEGAS OFFICE				

8. WELL CONSTRUCTION
 Depth Drilled 550 Feet Depth Cased _____ Feet

HOLE DIAMETER (BIT SIZE)
 From _____ To _____
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8"				

Perforations:
 Type perforation _____
 Size perforation _____
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal _____ Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From _____ feet to _____ feet

Date started 1-9-07
 Date completed 1-20-07

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

9. WATER LEVEL
 Static water level 323' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name T.D.C. Drilling
 Address 2870 W Pebble Rd
Las Vegas NV 89123
 Nevada contractor's license number 59948
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 2333-T1
 Division of Water Resources, the on-site driller
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 1-22-07