

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 102449
 Permit No. _____
 Basin 162



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 30193

1. OWNER Bauer ADDRESS AT WELL LOCATION 1440 W. Lost Creek Drive
 MAILING ADDRESS 1440 W. Lost Creek Drive Drive slg
Pahrump, NV 89060

2. LOCATION NE 1/4 NE 1/4 Sec. 29 T 20S N/S R 53E E Nye County
 PERMIT NO. 39-021-01 Calvada Valley Subdivision Name
 Issued by Water Resources Parcel No. _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>brown silty loam</u>		<u>0</u>	<u>4</u>	<u>4</u>
<u>grey loam</u>		<u>4</u>	<u>11</u>	<u>7</u>
<u>brown loam</u>		<u>11</u>	<u>21</u>	<u>10</u>
<u>brown caleche</u>		<u>21</u>	<u>25</u>	<u>4</u>
<u>brown loam</u>		<u>25</u>	<u>44</u>	<u>19</u>
<u>grey loam</u>	<u>x</u>	<u>44</u>	<u>89</u>	<u>45</u>
<u>brown loam</u>	<u>x</u>	<u>89</u>	<u>94</u>	<u>5</u>
<u>brown caleche</u>	<u>x</u>	<u>94</u>	<u>96</u>	<u>2</u>
<u>See next line</u>	<u>x</u>	<u>96</u>	<u>200</u>	<u>104</u>
<u>brown loam ith caleche strings</u>				

8. WELL CONSTRUCTION
 Depth Drilled 200 Feet Depth Cased 200+1 Feet

HOLE DIAMETER (BIT SIZE)
 From 11 Inches To 0 Feet 200 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>3.7</u>	<u>.280</u>	<u>0</u>	<u>200</u>

Perforations:
 Type perforation sawcut
 Size perforation .188

From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 200 feet

9. WATER LEVEL
 Static water level 66 feet below land surface
 Artesian flow _____ G.P.M. P.S.I.
 water temperature cool Quality good

DCNR/DWR
 RECEIVED
 FEB 26 2007
 LAS VEGAS OFFICE

Date started 2/9/2007 slg _____ 19____
 Date completed 2/9/2007 _____ 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift
 Draw Down (Feet Below Static)

G.P.M.	Time (Hours)

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Strickland Construction Co., Inc. Contractor
 Address 5801 S. Homestead Contractor
Pahrump, NV 89048

Nevada contractor's license number issued by the State Contractor's Board 40277
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086

Signed _____ By driller performing actual drilling on-site or contractor
 Date 2/16/07