WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No 102458
Permit No.
Basin 203

NOTICE OF INTENT NO. 30696

1. OWNER RODGER & SHIRLEY GASKILL
MAILING ADDRESS P.O. BOX 738
CALIENTE NV 89008
ADDRESS AT WELL LOCATION 12 PALOMINO LANE
CALIENTE NV 89008

2. LOCATION NE ¼ NW ¼ Sec. 35 T. 2-S N/S R. 67 E E. LINCOLN County
PERMIT NO. Issued by Water Resources | 012-230-27 Parcel No. | WILD HORSE FLAT Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
FINE SAND & SILT		0	22	22
SAND & GRAVEL		22	27	5
BROWN SANDY CLAY		27	36	9
FINE SAND		36	58	22
HARD BROWN SAND STONE		58	63	5
GRAVEL	YES	63	80	17
COBBLES	YES	80	84	4
GRAVEL	YES	84	96	12
COBBLES	YES	96	100	4

DCNR/DWR
RECEIVED
JAN 30 2007
LAS VEGAS OFFICE

Date started 01-01-07, 19
Date completed 01-25-07, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☑ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
22	3	1

8. WELL CONSTRUCTION
Depth Drilled 100 Feet Depth Cased 100 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8 3/4 Inches		0 Feet	100 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4 1/2	PVC	SCHED. 40	0	100

Perforations:
Type perforation VERTICAL
Size perforation 1/8" x 6" x 4 ROWS
From 61 feet to 100 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 51
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☑ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 100 feet to 51 feet

9. WATER LEVEL
Static water level 49.5 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 61 °F Quality SOME FINE SAND

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name R.C.B.B. INC. Contractor
Address 6411 W. DEERSPRING WAY Contractor
LAS VEGAS NV 89131
Nevada contractor's license number issued by the State Contractor's Board 0020301
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2064
Signed Jack Fulmer By driller performing actual drilling on site or contractor
Date 01-26-07

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627