



WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY  
Log No. 102506  
Permit No. \_\_\_\_\_  
Basin. 101

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

NOTICE OF INTENT NO. 54159

1. OWNER JKB Builders ADDRESS AT WELL LOCATION 1650  
MAILING ADDRESS \_\_\_\_\_ 5645 Cume Kaleb / Sky Ridge  
Fallon, NV (not 78)  
2. LOCATION SE 1/4 NW 1/4 Sec 20 T 19 N 28 E \_\_\_\_\_ County  
PERMIT NO. 008-173-12 Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_  
Issued by Water Resources

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand, Fine		1	26	
Clay (Blue)		26	39	
Blue Gravel				
Sand		39	43	
Sand Gravel		43	71	
Black Grey Clay		71	85	
1/3 Sand			119	
Brown Sand		85	100	
Coarse Gravel				
Grey Clay		119	120	

39.499267 N  
119.869267 W NAD83

8. WELL CONSTRUCTION  
Depth Drilled 120 Feet Depth Cased 120 Feet  
HOLE DIAMETER (BIT SIZE)  
5/8 Inches From 1 Feet To 120 Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>1 3/8</u>	<u>13</u>	<u>1.88</u>	<u>1</u>	<u>20</u>
<u>1 3/8</u>	<u>PVC</u>	<u>SN40</u>	<u>20</u>	<u>120</u>

Perforations:  
Type perforation Machine Part  
Size perforation 3/16" 4 x 5# news part  
From 100 feet to 110 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 50  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
From 20 feet to 120 feet

9. WATER LEVEL  
Static water level 28 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name [Signature] Contractor  
Address 10555 Contractor  
25 NW 39429  
Nevada contractor's license number issued by the State Contractor's Board 0031841  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1876  
Signed [Signature] By driller performing actual drilling on site or contractor  
Date 10/13/06

Date started 10/13/06, 20\_\_\_\_  
Date completed 10/19/06, 20\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>32</u>		<u>2 1/2</u>