WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 102518
Permit No
Basin 162

NOTICE OF INTENT NO. 30509

1. OWNER OAKLEY PROPERTIES
MAILING ADDRESS 4791 W HARDY
PAHRUMP, NV

ADDRESS AT WELL LOCATION 4791 W HARDY

2. LOCATION SW 1/4 SW 1/4 Sec. 14 T 20S N/S R 52E E NYE County
PERMIT NO Issued by Water Resources
41-493-10 Parcel No
GOLDEN SPRING RANCH #3 Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	84	84
CALICHE	WB	84	87	3
CLAY		87	131	44
CALICHE	WB	131	142	11
CLAY		142	167	25
CALICHE	WB	167	184	17
CLAY		184	200	16

DCNR/DWR
RECEIVED
APR 0 8 2007
LAS VEGAS OFFICE

Date started 4/3/2007 , 19__
Date completed 4/3/2007 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 inches		0 Feet	200 Feet
inches		Feet	Feet
inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	3.63	.250	0	200

Perforations:
Type perforation SAWCUT
Size perforation 1/8 X 3
From 140 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 200 feet

9. WATER LEVEL
Static water level 75 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO. OF NEVADA, INC. Contractor
Address 1220 E MANSE RD Contractor
PAHRUMP, NV. 89048
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed By driller performing actual drilling on-site or contractor
Date 4/3/2007

USE ADDITIONAL SHEETS IF NECESSARY