WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 102519
Permit No.
Basin 162

NOTICE OF INTENT NO. 30486

1. OWNER JUAN MARTINEZ
MAILING ADDRESS 520 E TRAIN WAY
PAHRUMP, NV

ADDRESS AT WELL LOCATION 520 E TRAIN WAY

2. LOCATION SW 1/4 SE 1/4 Sec. 10 T 19S N/S R 53E E NYE County
PERMIT NO. Issued by Water Resources
27-261-36 Parcel No.
Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [X] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
GRAVEL & CLAY		0	180	180
GRAVEL	WB	180	189	9
CEMENTED GRAVEL		189	216	27
GRAVEL	WB	216	305	89

8. WELL CONSTRUCTION
Depth Drilled 305 Feet Depth Cased 305 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	60	Feet
7 7/8	Inches	60	Feet	305	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5	2.36	0248	60	305

Perforations:
Type perforation SAWCUT
Size perforation 1/8 X 3
From 225 feet to 305 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured

Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 305 feet

9. WATER LEVEL
Static water level 180 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

Date started 3/21/2007 19
Date completed 3/23/2007 19

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO. OF NEVADA, INC. Contractor
Address 1220 E MANSE RD Contractor
PAHRUMP, NV. 89048.
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed By driller performing actual drilling on-site or contractor
Date 3/27/2007

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

USE ADDITIONAL SHEETS IF NECESSARY