

OFFICE USE ONLY  
 Log No. 102529  
 Permit No. 72284  
 Basin 212

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO 30606

1. OWNER Boyd Family Partnership ADDRESS AT WELL LOCATION Leon Ave - DSB  
 MAILING ADDRESS 2113 SILVER AVE  
LAS VEGAS NV 89102  
 2. LOCATION SW 1/4 SW 1/4 Sec. 13 T 19 S R 60 E CLARK County  
 PERMIT NO. 72284 125-13-402-004 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Caliche		0	50	
Clay + Caliche		50	135	
Caliche + Water		135	150	
Clay		150	470	
Clay + Water		470	500	
Caliche + Clay		500	590	
Caliche + Water		590	620	

8. WELL CONSTRUCTION  
 Depth Drilled 620 Feet Depth Cased 620 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
12 1/4 Inches 0 Feet 50 Feet  
9 7/8 Inches 50 Feet 620 Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>16.97</u>	<u>.188</u>	<u>+2</u>	<u>50</u>
<u>6 1/2</u>	<u>PVC</u>		<u>+1</u>	<u>620</u>

 Perforations:  
 Type perforation FACTORY  
 Size perforation .032 Sieve Type  
 From 590 feet to 610 feet  
 From 550 feet to 570 feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50 FT  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 03-09-07, 20  
 Date completed 03-21-07, 20

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>10:5 AM</u>	<u>91</u>	<u>2007 APR 16 AM 9:07</u>

9. WATER LEVEL  
 Static water level 116 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cool °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name VERNON H. DIMICK Contractor  
 Address 5360 N. BONITA VISTA ST  
LAS VEGAS, NEV. 89149  
 Nevada contractor's license number issued by the State Contractor's Board 10062  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552  
 Signed V.H. Dimick  
 By driller performing actual drilling on site or contractor  
 Date 03-21-07