

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 30605

1. OWNER Boyd Family Partnership ADDRESS AT WELL LOCATION Leon Ave - DSB
 MAILING ADDRESS 2113 SILVER AVE LAS VEGAS, NEV 89102
 2. LOCATION SW 1/4 SW 1/4 Sec. 13 T. 19 S. R. 60 E. CLARK County
 PERMIT NO. 72285 Issued by Water Resources Parcel No. 125-13-402-002 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY		0	25	
Caliche		25	70	
CLAY + CALICHE		70	150	
CLAY + WATER		150	160	
CLAY		160	480	
Caliche + WATER		480	500	
CLAY		500	650	
Caliche + WATER		650	705	

8. WELL CONSTRUCTION
 Depth Drilled 705 Feet Depth Cased 705 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
12 1/4 Inches 0 Feet 5.0 Feet
9 7/8 Inches 5.0 Feet 705 Feet
 Casing Schedule

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>16.97</u>	<u>.188</u>	<u>+2</u>	<u>50</u>
<u>6 1/2</u>	<u>Pipe</u>		<u>+1</u>	<u>705</u>

 Perforations:
 Type perforation FACTORY
 Size perforation .032 Sieve Type
 From 675 feet to 695 feet
 From 635 feet to 655 feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 ft. Neat Cement
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From _____ feet to _____ feet
 9. WATER LEVEL
 Static water level 118 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cool °F Quality _____

Date started 03-14-07, 20_____
 Date completed 03-21-07, 20_____
 7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>10-6</u>	<u>16</u>	<u>9:07</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Vernon H. Dimick Contractor
 Address 5360 N. BONITA VISTA ST. LAS VEGAS, NEV 89149
 Nevada contractor's license number issued by the State Contractor's Board 10062
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552
 Signed VH Dimick
 By driller performing actual drilling on site or contractor
 Date 03-21-07