WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 102531
Permit No.
Basin 212

NOTICE OF INTENT NO. 31013

1. OWNER Joey De Blanco
MAILING ADDRESS 2251 N Rampart Blvd #418 Las Vegas NV 89128
ADDRESS AT WELL LOCATION Corner of Tioga Way and Verde Way, Las Vegas

2. LOCATION SW ¼ SW ¼ Sec. 34 T. 19 N/S R. 60 E. Clark County
PERMIT NO. _____ Issued by Water Resources | 125-34-410-101 Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
With Pulstar pump truck we pulled system from the well. Abandoned 8" well to 400' Depth. Existing perforations from 400' to 350'. Restriction found in casing at 175', because of this we were unable to get perforator (mill knife) past restriction. Perforated from 175' to 50' Waiver # R-1361 Pumped 14 yards of neat cement through a tremmie hose from the bottom of the well to 32' from the top of the well. Poured concrete grout from 32' to the surface completely filling well.				
Waiver # R-1361				

Date started 3/23/ 2007
Date completed 4/9/ 2007

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
	RECEIVED	
	APR 10 2007	
	LAS VEGAS	

8. WELL CONSTRUCTION
Depth Drilled 400 Feet Depth Cased _____ Feet

HOLE DIAMETER (BIT SIZE)
From To
_____ Inches _____ Feet _____ Feet
_____ Inches _____ Feet _____ Feet
_____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8"				

PLUGGED BY GWMP
ORIG PLUG LOG # 60365

Perforations:
Type perforation
Size perforation
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☐ No
From _____ feet to _____ feet

9. WATER LEVEL
Static water level 111' feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name T.D.C. Drilling Contractor
Address 2870 W Pebble Rd Contractor
Las Vegas NV 89123
Nevada contractor's license number issued by the State Contractor's Board 59948
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2316
Signed [signature] By driller performing actual drilling on site or contractor
Date 4/10/07

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (G)-627