WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 102605
Permit No.
Basin 212

NOTICE OF INTENT NO. 30299

1. OWNER Jeff Gibson, American Pacific Corp.
MAILING ADDRESS 5770 Howard Hughes Pkwy, Las Vegas, NV 89109
ADDRESS AT WELL LOCATION Along the Russell Rd alignment E. of Sam Boyd Stadium, SW of archery range - Henderson, NV
2. LOCATION SE ¼ SW ¼ Sec. 25 T. 21 N ⊗ R. 62 E. County
PERMIT NO. Issued by Water Resources
Parcel No. 161-254-01-001
Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other Rotasonic

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silty Sand + gravel		0	5'	
Sand + gravel	X	5'	20'	
caliche - Sand + gravel	X	20'	25'	
caliche - Sand + gravel	X	25'	51'	
with cobbles	X			
Silty clay		51'	55'	
GPS = 115.007110 /	36.	0855	88	
casting 826443				
Northing 26733285				

Date started March 23, 2007
Date completed March 23, 2007

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 55 Feet Depth Cased 45 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8" Inches	0 Feet	45' Feet
6" Inches	45 Feet	55 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"	Sch 40	.474	23'	0

Perforations:
Type perforation Factory cut
Size perforation .080
From 23' feet to 42' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 20 feet
Placement Method: ☑ Pumped volclay grout ☑ Poured 3/8 chips
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 20' feet to 43' feet

9. WATER LEVEL
Static water level 15.8' feet below land surface
Artesian flow No G.P.M. N/A P.S.I.
Water temperature N/A °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Bract Longyear Contractor
Address 7773 W. Seldon Ln Contractor
Peoria, Az 85345
Nevada contractor's license number issued by the State Contractor's Board 0010157
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M2148
Signed [signature] By driller performing actual drilling on site or contractor
Date 3-27-07

(Rev. 12-02)

USE ADDITIONAL SHEETS IF NECESSARY

10-627