WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

003601R

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

4 WELLS

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 102617
Permit No.
Basin 212

NOTICE OF INTENT NO. 30679

1. OWNER Rose Pelino
MAILING ADDRESS 6 Sylvan Way
Parsippany NJ

ADDRESS AT WELL LOCATION 5164 Route A Car Rd
Las Vegas NV

2. LOCATION SE ¼ NW ¼ Sec. 27 T. 21 N/S R. 61 E. Clark County

PERMIT NO. _____ Issued by Water Resources | 162-27-201-005 Parcel No. | _____ Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphalt		0.0	0.2	0.2
Type II		0.2	1.0	0.8
Silty Clay		1.0	11.0	10.0
Caliche		11.0	13.0	2.0
Sandy Clay		13.0	23.5	10.5
Silty Sand		23.5	65.0	41.5

MAP DATUM
WGS 84

MW-45B 36° 05.817N 115° 08.956 W
MW-45C 36° 05.818N 115° 08.955 W
MW-48B 36° 05.838N 115° 08.734 W
MW-48C 36° 05.837N 115° 08.733 W

Date started 3/14, 2007
Date completed 3/21, 2007

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 65/25 Feet Depth Cased 65/25 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8½ Inches	0.0 Feet	65.0 Feet
8½ Inches	0.0 Feet	25.0 Feet
8½ Inches	0.0 Feet	30.0 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.0		Sch 40 PVC	0.0	65.0
2.0		Sch 40 PVC	0.0	25.0
2.0		Sch 40 PVC	0.0	30.0

Perforations:
Type perforation Machine Slot
Size perforation .020
From 65.0 feet to 60.0 feet
From 25.0 feet to 20.0 feet
From 30.0 feet to 25.0 feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 1'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 65 / 25/30 feet to 58 / 18/23 feet

9. WATER LEVEL
Static water level 23.5 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Eagle Drilling Services LLC
Contractor
Address 7150 Placid St.
Contractor
Las Vegas Nv. 89119

Nevada contractor's license number issued by the State Contractor's Board 51266

Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2272

Signed [signature]
By driller performing actual drilling on site or contractor

Date 3/21/07

(Rev. 12-01)

USE ADDITIONAL SHEETS IF NECESSARY