


STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 102620
 Permit No. _____
 Basin D97B

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK



Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 57826

1. OWNER Carol Madden
 MAILING ADDRESS 875 Matterhorn Blvd.
Reno, NV 89506
 ADDRESS AT WELL LOCATION 875 Matterhorn Blvd.

2. LOCATION NE 1/4 NE 1/4 Sec. 15 T 21N N/S R 19E E Washoe County
 PERMIT NO. DOM06-034 080-413-05 Hepner # 4
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Weatherd granite with some clay		183	197	14
Gray granite		197	211	14
Weatherd granite some clay		211	218	7
Weatherd granite		218	251	33
Brown clay		251	259	8
Weatherd granite		259	311	52
Weatherd granite with clay streaks		311	323	12
Dark gray granite hard		323	359	36
Fracture	x	359	361	2
Gray granite		361	373	12
Fracture with clay	x	373	378	5
Gray hard granite		378	390	12

Washoe County Permit # WL 060205

NAD 83
 N 39.69073
 W 119.82982

8. WELL CONSTRUCTION
 Depth Drilled 390 Feet Depth Cased 390 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
<u>6 1/8</u> Inches	<u>183</u> Feet	<u>390</u> Feet
_____ Inches	_____ Feet	_____ Feet
_____ Inches	_____ Feet	_____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>5</u>	<u>10.79</u>	<u>.188</u>	<u>170</u>	<u>390</u>

Perforations:
 Type perforation Machine cut
 Size perforation 3/32 x 3

From	To
<u>340</u> feet	<u>380</u> feet
_____ feet	_____ feet
_____ feet	_____ feet
_____ feet	_____ feet
_____ feet	_____ feet

Surface Seal: Yes No
 Depth of Seal _____
 Placement Method: Pumped Poured
 Seal Type: Neat Cement Cement Grout Concrete Grout

Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 148 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cool °F Quality Not tested

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. Contractor
 Address 1600 Mt. Rose Hwy Contractor
Reno, NV 89511
 Nevada contractor's license number issued by the State Contractor's Board 23096
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923

Signed R. Bruce MacKay
 By driller performing actual drilling on-site or contractor
 Date 11/27/2006

Date started 11/13/2006, 19
 Date completed 11/20/2006, 19

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Bailer Draw Down (Feet Below Static)	Pump Time (Hours)	Air Lift Time (Hours)
Air	6-8			
Pump	6	200	2 Hrs	

RECEIVED
 2006 DEC 6 AM 10:59
 STATE ENGINEERS OFFICE