REPORT NO. A06.078

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

LOG NO. 102626
PERMIT NO.
BASIN 097

NOTICE OF INTENT NO. 58748

1. OWNER Nick & Cindy Grant
ADDRESS OF WELL Herlong Road
MAILING ADDRESS 5315 Sun Valley Blvd #20, Sun Valley, NV 89433
Reno, NV

2. WELL LOCATION NE` 1/4 SE 1/4 SEC. 28 T 26 R 18 E Washoe COUNTY

PERMIT NO ____ PARCEL NO 074-062-64 SUBDIVISION NAME Pyramid Lake Ranches

3. TYPE OF WORK
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Plug [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Mud

6. LITHOLOGIC LOG

MATERIAL	STRATA	FROM	TO	THICKNESS
Sands, Gravels & Brown Clay		0	10	10
Blue Chipped Rock Lt Brown Clay		10	18	8
Green Clay, Some Brown		18	80	62
Dark Blue Grn Clay Some VR Rock		80	90	10
Dark Grn, Blue Grn Clay		90		
Some Small Rock		90	110	20
Blue Green Thick Clay		110	480	370
Some Light Yellow Mixed		480	500	20
Dark Blue Green Clay		500	540	40
Specs Of White Clay Mixed		540	560	20
Dark Blue Grn & Gray Clay		560	658	98

2006 OCT 23 PM 12:25 STATE ENGINEER'S OFFICE

Notes : WGS-84 GPS: Latitude N40 5.570 Longtitude: W119 57.730

N40.092833
W119.962167 NAD83

Date Started 09/25/2006 Date Completed 10/06/2006

7. WELL TEST DATA

TEST METHOD [ ] Bailer [ ] Pump [X] Air Develop

	GPM	DRAWDOWN	TIME (HRS)
	20+		3.25

8. WELL CONSTRUCTION

Depth Drilled 658' Depth Cased 658'

HOLE DIAMETER (BIT SIZE)

13 Inches 0 Feet 50 Feet
10 5/8 Inches 50 Feet 360 Feet
9 7/8 Inches 360 Feet 658 Feet

CASING SCHEDULE

Size OD	Weight/Ft	Wall Thickness	From	To
8 5/8"	16.94	.188	+2	658'

PERFORATIONS:
Type Perforation Double Size Perforation 3/32 X3
From 534 Feet to 554 Feet
From 596 Feet to 616 Feet
From ____ Feet to ____ Feet

SURFACE SEAL: [X] Yes [ ] No
Seal Depth 50'
PLACEMENT METHOD: [X] Pumped [ ] Poured

SEAL TYPE:
[X] Neat Cement
[ ] Cement Grout
[ ] Concrete Grout
[ ] Bentonite

GRAVEL PACKED: [ ] Yes [X] No
From ____ Feet to ____ Feet

9. WATER LEVEL
Static Water Level 133 Feet Below Land Surface
Artesian Flow ____ GPM ____ PSI
Water Temperature Warm F Quality ____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of m knowledge.

Name Aqua Drilling & Well Service
Address 675 Edison Way
Reno, NV 89502

NV. CONTRACTOR'S LIC. NO. 15291 DRILLER'S LIC. NO. ON SITE 2189

Signed [signature]
By driller performing actual drilling on site or contractor

Dated October 19, 2006