


PRINT OR TYPE ONLY
DO NOT WRITE ON BACK



WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 56182

1. OWNER Tim Pemberton ADDRESS AT WELL LOCATION 3648 Antelope
MAILING ADDRESS TRE
2. LOCATION SW 1/4 NW 1/4 Sec 21 T. 10 N/S R. 22 E Douglas Co County
PERMIT NO. 102200-002-020 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other mul

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>slit + Broken D-6</u>		<u>0</u>	<u>14'</u>	<u>14"</u>
<u>Broken D-6</u>		<u>14</u>	<u>200'</u>	<u>86"</u>
<u>Hard Granite</u>		<u>200</u>	<u>278</u>	<u>98"</u>
<u>Broken Granite</u>		<u>278</u>	<u>356'</u>	<u>58"</u>
<u>60ps</u>				
<u>38° 43.112 N</u>				
<u>119° 31.767 W</u>				
<u>38.718533 N</u>				
<u>119.529450 W NAD83</u>				

8. WELL CONSTRUCTION
Depth Drilled 356' Feet Depth Cased 357' Feet
HOLE DIAMETER (BIT SIZE) 3 5/8
From 0 To 356'
Inches 11" Feet 0 Feet 356'
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>13 lbs</u>	<u>1.88</u>	<u>+1</u>	<u>16'</u>
<u>6 7/8</u>	<u>pipe</u>	<u>SDR 21</u>	<u>16</u>	<u>356'</u>

Perforations:
Type perforation Sawed
Size perforation 18 x 4" 5 ROWS
From _____ feet to _____ feet
From 294' feet to 356' feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 60' Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From 60' feet to 356' feet

9. WATER LEVEL
Static water level 144' feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature 61 °F Quality Clear

Date started 9/11/06 20____
Date completed 9/12/06 20____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>15</u>	<u>60m</u>	<u>3 1/2 hr</u>

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the reports true to the best of my knowledge.
Name Seal Drilling Inc. Contractor
Address PO Box 599 Contractor
Salmon Springs NV 89429
Nevada contractor's license number 31841 issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1740
Signed T. J. Leach
By driller performing actual drilling on site or contractor
Date Oct 13 2006