WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 10d650
Permit No.
Basin Ø49

NOTICE OF INTENT NO. 58026

1. OWNER Avila, Jesus & Jose
MAILING ADDRESS
ADDRESS AT WELL LOCATION Nana Establishe Express Drive

2. LOCATION SW ¼ NE ¼ Sec. 9 T. 35 N/S R. 52 E. Elko County
PERMIT NO. N/A Issued by Water Resources | 035-051-002 Parcel No. | Meadow Valley Ranchos #3 Blk 51, Lot 2 Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☑ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Soil & sandy clay		0	3	3
Sandy clay & gravel		3	7	4
Gravel	✓	7	8	1
Clay, sand, gravel	✓✓	8	19	11
Sandy clay		19	117	98
Gravel	✓✓	117	118	1
Streaks of clay, sand & gravel	✓✓	118	150	32
Sandy clay		150	156	6
GPS location 40.93652 N 115.66860 W NAD-27				
N 40.936440 W 115.669501 NAD 83				

Date started 11-16-06, 19
Date completed 12-13-06, 19

7. WELL TEST DATA
TEST METHOD: ☑ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15	63	

8. WELL CONSTRUCTION
Depth Drilled 156 Feet Depth Cased ~~157~~ 156 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	100 Feet
8 Inches		100 Feet	150 Feet
6 Inches		150 Feet	156 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+1	156

Perforations:
Type perforation Torch Cut
Size perforation
From 115 feet to 150 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 100 ft
Placement Method: ☑ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout & Bentonite

Gravel Packed: ☑ Yes ☐ No
From 100 feet to 150 feet

9. WATER LEVEL
Static water level 37 feet below land surface
Artesian flow no G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Meth Drilling Co. Contractor
Address 203 Pine St. Elko, NV 89801 Contractor

Nevada contractor's license number issued by the State Contractor's Board 10819
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 632
Signed James V. Meth By driller performing actual drilling on site or contractor
Date 12-18-06

RECEIVED 2006 DEC 26 AM 10:28 STATE ENGINEER'S OFFICE

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627