WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 102665
Permit No.
Basin 056

NOTICE OF INTENT NO. 59270

1. OWNER Lander County
MAILING ADDRESS PO Box 144
Austin NV 89310
ADDRESS AT WELL LOCATION Pony Canyon Rd
495669m E / 4370012m N Ele 7165
UTM Zone 11 - NAD27

2. LOCATION SW 1/4 NE 1/4 Sec. 29 T. 19 N/S R. 44 E Lander County
PERMIT NO. 20157 Issued by Water Resources | N/A Parcel No. | N/A Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☑ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☑ Air ☑ Other Horizontal

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Topsoil/Cobbles		0	12	12
Weathered - Highly				
Fractured Austin Pluton		12	87	75
Fractured Austin Pluton 120+		87	400	313

N 39.481502
W 117.051281 NAD83

RECEIVED 2006 DEC 14 AM 10:54 STATE ENGINEER'S OFFICE

Date started Nov 15th, 2006
Date completed Nov 21st, 2006

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
6	N/A	24 hours

Test Method:
Gravity Feed

8. WELL CONSTRUCTION
Depth Drilled 400 Feet Depth Cased 400 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
7 Inches		0 Feet	95 Feet
5.5 Inches		95 Feet	400 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6		.250	+2	95
1½		Sch 80 PVC	+2	400

Perforations:
Type perforation 6" = torch 1½ = Machine slots
Size perforation 6" = ⅛" 1½ = .020
From 6" ⅛" - 20 feet to 95 feet
From 1½ - 120 feet to 400 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 95'
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☑ No
From feet to feet

9. WATER LEVEL
Static water level N/A feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature Cool °F Quality 6 gpm - gravity flow

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Jensen Drilling Company (Contractor)
Address 1775 Henderson Ave (Contractor)
Eugene OR 97403
Nevada contractor's license number issued by the State Contractor's Board 041287
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2332
Signed (By driller performing actual drilling on site or contractor)
Date 12/11/06

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627