WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 102682
Permit No.
Basin 212

NOTICE OF INTENT NO. 31012

1. OWNER LeHuong Thi
MAILING ADDRESS 9978 Shadow Gate Ct, Las Vegas NV 89148
ADDRESS AT WELL LOCATION 8900 Gilespie Street, Las Vegas NV 89123

2. LOCATION SE ¼ SW ¼ Sec 16 T 22 N/S R 61 E Clark County
PERMIT NO. (Issued by Water Resources) 177-16-406-005 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
With Pulstor pump truck we pulled system from the well. Abandoned 8" well to 290' Depth. Existing perforations from 290' to 230' Perforated casing with mill knife perforator from 230' to 185' Pumped 9 yards of neat cement through a tremmie hose from the bottom of the well to 42 feet from the top of the well Poured 1.4 yards of concrete grout from 42' to the surface completely filling the well				
PLUGGED BY GWMP PLUG LOG # 59353				
deepening				

Date started 4/9/, 2007
Date completed 4/16/, 2007

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 290' Feet Depth Cased Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8"	Inches	Feet	Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 121 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name T.D.C Drilling (Contractor)
Address 2870 W. Pebble Rd (Contractor)
Las Vegas NV 89123
Nevada contractor's license number issued by the State Contractor's Board 59948
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2267
Signed (By driller performing actual drilling on site or contractor)
Date 4/16/07

(Rev. 12-01)

USE ADDITIONAL SHEETS IF NECESSARY

(06-07)