

102696  
 OFFICE USE ONLY  
 Log No. 102696  
 Permit No. 56344T  
 Basin. 212

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 30926

1. OWNER Las Vegas Valley Water District ADDRESS AT WELL LOCATION 351 S. Valley View Blvd. Las Vegas, NV 89153  
 MAILING ADDRESS 2001 S. Valley View Blvd. Las Vegas, NV 89153  
 2. LOCATION SE 1/4 SW 1/4 Sec. 29 T. 20 N. R. 61 E. Clark County  
 PERMIT NO. 56344T Issued by Water Resources Parcel No. 13929401001 Subdivision Name NONE

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Install Blank Patches to Screen area 630'-690'				
5x12' Patches				
1x4' Patch				
Bail Fill From Bottom 1226'-1260'				

8. WELL CONSTRUCTION  
 Depth Drilled 1280 Feet Depth Cased 1,250 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 40 Inches 0 Feet 159 Feet  
 To 30 Inches 159 Feet 1,280 Feet  
 Casing Schedule  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>32</u>			<u>0</u>	<u>159</u>
<u>20</u>			<u>+3</u>	<u>1,250</u>

 Perforations:  
 Type perforation Houston 3x Stron Screen  
 Size perforation .39" Steel, .08 slot  
 From 300 feet to 350 feet  
 From 630 feet to 690 feet  
 From 850 feet to 910 feet  
 From 1140 feet to 1240 feet  
 Surface Seal:  Yes  No Seal Type:  Neat Cement  
 Depth of Seal 5' to 159'  Cement Grout  
 Placement Method:  Pumped  Concrete Grout  
 Poured  
 Gravel Packed:  Yes  No  
 From 0 feet to 1,280 feet

Date started 4-9-07, 2007  
 Date completed 4-13, 2007

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>N/A</u>			
<u>A</u>		<u>61:19</u>	<u>2007 APR 25 AM 10:25</u>

9. WATER LEVEL  
 Static water level 21.00 feet below land surface  
 Artesian flow NONE G.P.M. N/A P.S.I.  
 Water temperature N/A °F Quality N/A

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Las Vegas Valley Water District  
 Address 1001 S. Valley View Blvd. Las Vegas, NV 89153  
 Nevada contractor's license number issued by the State Contractor's Board NONE  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller R4P LTO-2171  
 Signed JASON SHAW  
 Date 4-16-07