WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirely in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 102713
Permit No.
Basin 162

NOTICE OF INTENT NO. 28315

1. OWNER RICARDO RESTREPO
MAILING ADDRESS 1341 W GRAY FOX WAY
PAHRUMP, NV

ADDRESS AT WELL LOCATION 1341 W GRAY FOX WAY

2. LOCATION SW 1/4 SE 1/4 Sec. 20 T 20S N/S R 53E E NYE County
PERMIT NO. 39-045-01 (Issued by Water Resources / Permit No.)
CLAVADA VALLEYUNIT 8B (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY & CALICHE		0	65	65
CALICHE	WB	65	91	6
CLAY		91	127	36
CALICHE	WB	127	134	7
CLAY		134	157	23
CALICHE	WB	157	166	9
CLAY		166	184	18
CALICHE	WB	184	196	12
CLAY		196	214	18
CALICHE	WB	214	220	6

DCNR/DWR
RECEIVED
APR 25 2007
LASVEGASOFFICE

Date started 4/10/2007 , 19__
Date completed 4/10/2007 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 220 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	220	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	3.63	.250	0	220

Perforations:
Type perforation SAWCUT
Size perforation 1/8 X 3

From	160	feet to	220 feet
From		feet to	feet
From		feet to	feet
From		feet to	feet
From		feet to	feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed. [X] Yes [ ] No
From 50 feet to 220 feet

9. WATER LEVEL
Static water level 65 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name LARRY'S WATER WELL SERVICE (Contractor)
Address P.O BOX 3392 (Contractor)
PAHRUMP, NV. 89041
Nevada contractor's license number issued by the State Contractor's Board ~~47353~~ 35901
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed (By driller performing actual drilling on-site or contractor)
Date 4/11/2007

USE ADDITIONAL SHEETS IF NECESSARY