STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 102801
Permit No.
Basin 045

NOTICE OF INTENT NO. 59026

1. OWNER JERRY DEPALMA
MAILING ADDRESS P. O. BOX 281726, LAMOILLE,NV 89828

ADDRESS AT WELL LOCATION 180 BUCKSKIN DRIVE
Subdivision Name: DYSART County: ELKO

2. LOCATION ~~NW~~ NE ¼ ~~NE~~ SW ¼ Sec 28 T 33N N/S R 58 E
PERMIT/WAIVER No. 007-080-113
Issued by Water Resources Parcel No.

Latitude
Longitude
UTM E 0631494 N 4508270 ☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC ☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	2	2
CLAY & GRAVEL		2	16	14
GRAVEL & BOULDERS &		16		
SOME CLAY MIX			40	24
GRAVEL SOME BOULDERS		40	140	100
& SILTSTONE MIX				
GRAVEL	150	140	160	20
BOULDERS & SOME GRAVEL		160	185	25

N40.714950
W115.442305 NAD83

N 40.714950
W 115.442305 NAD27

Date started: 19-Jan , 20 07
Date completed: 22-Jan , 20 07

9. WELL CONSTRUCTION
Depth Drilled 185 Feet Depth Cased 185 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10-5/8	Inches	0	Feet	185	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	13	.188	+1	185

Perforations:
Type of perforation MILL SLOT
Size of perforation 3/16X3
From 165 feet to 185 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 5 to 15 ☐ Pumped ☒ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 50 to 185 ☐ Pumped ☒ Poured
Type: PEA GRAVEL
Bentonite Chips: ☒ Yes ☐ No 15 to 50 ☐ Pumped ☒ Poured
Type: 3/8 CHIPS

7. Water Level
Static water level: 130 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: COLD °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30		3

2007 FEB 28 AM 11:17

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HACKWORTH DRILLING, INC. (Contractor)
Address P. O. BOX 850 (Contractor)
ELKO, NV 89803
Nevada contractor's license number issued by the *State Contractor's Board* 020582
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1689
Signed (By driller performing actual drilling on site or contractor)
Date 1/24/2007

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY