WASHOE #WL060120

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

office use only
Log No. 102857
Permit No.........
Basin 087

NOTICE OF INTENT NO 57330

1. OWNER Scott Huber
MAILING ADDRESS **1635 Monte Vista**
Reno, NV 89511

ADDRESS AT WELL LOCATION **1635 Monte Vista**
Latitude N 39.26.011
Longitude W 119.46.726 WGS 84

2. Location **SW** 1/4 **SE** 1/4 Sec 7 T **18** N R **20** E **Washoe** County
PERMIT NO. PARCEL NO. **044-362-12** SUBDIVISION NAME

3. WORK PERFORMED
x New Well x Replace Recondition
Deepen Abandon Other

4. PROPOSED USE
X Domestic Irrigation Test
Municipal/Industrial Monitor Stock

5. WELL TYPE
Cable x Rotary RVC
Air Other x Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand and Bloder		0	38	38
Clay		38	59	21
Sand and Cobbles		59	172	113
Clay		172	220	48
Sand and Gravel		220	250	30
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0

N 39.433624
W 119.777763 NAD27

RECEIVED
2007 FEB -5 AM 11:55
STATE ENGINEERS OFFICE

N 39.433535
W 119.778784 NAD83

Date started **10/28** -06
Date completed **11/8** -06

8. WELL CONSTRUCTION
Depth Drilled **250** feet Depth Cased **250** feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12 1/4	inches	**0**	feet	**190**	feet
8 3/4	inches	**190**	feet	**250**	feet
	inches		feet		feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To Feet
6 5/8	**12.9**	**188**	**+1 1/2**	**250**

Perforations::
Type Perforation **Factory**
Size perforation **3/32 x 3**
From **130** feet to **150** feet
From **230** feet to **250** feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal X YES No
Depth of Seal **100** feet
x Pumped
Poured

Seal Type:
Neat Cement
x Cement Grout
Concrete Grout

Gravel Packed: x Yes No
From **100** feet to **250** feet

9 WATER LEVEL
Static water level **40** feet below land surface
Artesian flow GPM **0** P.S.I.
Water Temperature **cool** Degrees F Quality

7. WELL TEST DATA
TEST METHOD: Bailer Pump x Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (hours)
15	100	
30	**175**	
40	250	

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **McKay Drilling, Inc.**
4850 Joule St.
Reno, NV 89502
NV Contractors No. **14170**
NV Driller's Lic (on site) **2121**

Signed Steve McKay
By driller performing actual drilling on site or contractor

Date 11/9 -06