

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

office use only  
 Log No. 102838  
 Permit No. ....  
 Basin 088

NOTICE OF INTENT NO 58981

1. OWNER **Ward Chilton**  
 MAILING ADDRESS **1900 Manzanita**  
**Reno, NV 89509**

ADDRESS AT WELL LOCATION **Paddlewheel Ln.**  
 Latitude N 39.14.196  
 Longitude W 119.48.927 *W6584*

2. Location **NW 1/4 SE 1/4 Sec 4 T 17 N R 20 E** **Washoe** County  
 PERMIT NO. **PARCEL NO. 017-380-12** **SUBDIVISION NAME**

3. WORK PERFORMED			4. PROPOSED USE			5. WELL TYPE		
<input checked="" type="checkbox"/> New Well	Replace	Recondition	<input checked="" type="checkbox"/> Domestic	Irrigation	Test	Cable	<input checked="" type="checkbox"/> Rotary	RVC
Deepen	Abandon	Other	Municipal/Industrial	Monitor	Stock	Air	Other	<input checked="" type="checkbox"/> Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Black Clay		0	5	5
Gray Granite		5	151	146
Sand and Clay		151	200	49
Gravel and Sand		200	250	50

8. WELL CONSTRUCTION

Depth Drilled	250 feet	Depth Cased	250 feet
HOLE DIAMETER (BIT SIZE)			
	From	To	
11 inches	0 feet	250 feet	feet
			feet
			feet
CASING SCHEDULE			
0	Size O.D.   Weight/Ft.	Wall Thickness   From   To	
0	(Inches)   (Pounds)	(Inches)   (Feet)   Feet	
0	6 5/8   12.9	188   1 1/2   250	
0			
0			
0	Perforations::		
0	Type Perforation	Factory	
0	Size perforation	3/32 x 3	
0	From	198 feet to 238 feet	
0	From	feet to feet	
0	From	feet to feet	
0	From	feet to feet	
0	From	feet to feet	
0	From	feet to feet	
0	Surface Seal	<input checked="" type="checkbox"/> YES No	Seal Type:
0	Depth of Seal	105 feet	Neat Cement
0		<input checked="" type="checkbox"/> Pumped	<input checked="" type="checkbox"/> Cement Grout
0		Poured	Concrete Grout
0	Gravel Packed:	<input checked="" type="checkbox"/> Yes No	
0	From	105 feet to 250 feet	
0			
0	9 WATER LEVEL		
0	Static water level	30 feet below land surface	
0	Artesian flow	20 GPM 0 P.S.I.	
0	Water Temperature	cool Degrees F	Quality unkn

*N 39,236705*  
*W 119.814448 N4027*  
~~39,236705~~  
~~119.814448 N4027~~

RECEIVED  
 2007 FEB -5 AM 11:55  
 STATE ENGINEERS OFFICE

Date started **10/5 -06**  
 Date completed **10/9 -06**

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	x	Air Lift
G.P.M.	Draw Down (Feet Below Static)			Time (hours)
15	150			1/2
18	175			1/2
25	225			1/2
25	250			1

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name **McKay Drilling, Inc.**  
**4850 Joule St.**  
**Reno, NV 89502**  
 NV Contractors No. **14170**  
 NV Driller's Lic (on site) **2292**  
 Signed *Steve McKay*  
 By driller performing actual drilling on site or contractor  
 Date **10/9/06**