

REPORT NO **A07.04**



STATE OF NEVADA  
DIVISION OF WATER RESOURCES

**WELL DRILLER'S REPORT**

LOG NO. 102844  
PERMIT NO. 50472  
BASIN 492B

NOTICE OF INTENT NO. 58775

1. OWNER **Webb Mobile Home Park**  
MAILING ADDRESS **9660 N. Virginia St, Reno, NV 89506**

ADDRESS OF WELL **9660 N. Virginia**  
**Reno, NV 89506**

2. WELL LOCATION **NE** 1/4 **SW** 1/4 SEC. **8** T **20** R **19** E **Washoe** COUNTY  
PERMIT NO **50472** PARCEL NO **82-101-05** SUBDIVISION NAME \_\_\_\_\_

3. TYPE OF WORK

New Well  Replace  Recondition  
 Deepen  Plug  Other

4. PROPOSED USE

Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE

Cable  Rotary  RVC  
 Air  Mud

6. LITHOLOGIC LOG

MATERIAL	STRATA	FROM	TO	THICKNESS
Brown Clay & Sand		0	235	235
Gray Rock Hard		235	250	15
Red Clay & Black Rock		250	255	5
Black, Gray & Red Rock Hard		255	275	20
Gray Rock & Clay Hard		275	305	30
Black & Red Rock & Clay Hard		305	330	25
Multi Colored Rock		350	397	47
Hard Black Rock		397	440	43
Gravel		440	455	15
Hard Black Rock		455	458	3
<i>Old well under well Log # 11231</i>				
<i>2007 FEB - 1 AM 11:16 STATE ENGINEERS OFFICE</i>				

8. WELL CONSTRUCTION

Depth Drilled **458'** Depth Cased **458'**

HOLE DIAMETER (BIT SIZE)

**10 5/8** Inches **0** Feet **270** Feet  
**9 7/8** Inches **270** Feet **397** Feet  
**5 7/8** Inches **397** Feet **458** Feet

CASING SCHEDULE

Size OD	Weight/Ft	Wall Thickness	From	To
<b>6 5/8"</b>	<b>18.97</b>	<b>.280</b>	<b>+2'</b>	<b>397"</b>
<b>5"</b>	<b>9.66</b>	<b>.188</b>	<b>378'</b>	<b>458'</b>

PERFORATIONS:

Type Perforation **Factory** Size Perforation **DbI & Trp**  
From **297** Feet to **397** Feet  
From **378** Feet to **458** Feet  
From \_\_\_\_\_ Feet to \_\_\_\_\_ Feet

SURFACE SEAL:

Yes  No SEAL TYPE:  
 Neat Cement  
 Cement Grout

PLACEMENT METHOD:

Pumped  Concrete Grout  
 Poured  Bentonite

GRAVEL PACKED:

Yes  No  
From **50** Feet to **397** Feet

Notes : **WGS-84 GPS: Latitude: N39 36.782 Longitude: W119 52.459**

**N 39.613144**  
**W 119.873308 NAD27**

**N 39.613053**  
**W 119.874336 NAD83**

Date Started **12/07/2007**

Date Completed **01/12/2007**

7. WELL TEST DATA

TEST METHOD  Bailer  Pump  Air Develop

	GPM	DRAWDOWN	TIME (HRS)
<b>Air</b>	<b>20+</b>		<b>3</b>
<b>Pump</b>	<b>37 GPM</b>	<b>280</b>	<b>7</b>

9. WATER LEVEL

Static Water Level **120** Feet Below Land Surface  
Artesian Flow \_\_\_\_\_ GPM \_\_\_\_\_ PSI  
Water Temperature **Cool** F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **Aqua Drilling & Well Service, Inc**

Address **675 Edison Way**

**Reno, NV 89502**

DRILLER'S LIC. NO. \_\_\_\_\_  
NV. CONTRACTOR'S LIC. NO. **15291** ON SITE **2275**

Signed *Roger M. Thiel*

By driller performing actual drilling on site or contractor

Dated **January 31, 2007**