REPORT NO. A07.003

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

LOG NO. 102845
PERMIT NO.
BASIN Ø92A

NOTICE OF INTENT NO. 58771

1. OWNER Robin & Debi Bradley
MAILING ADDRESS 10805 Outlaw Lane, Reno, NV 89506

ADDRESS OF WELL 10805 Outlaw Lane
Reno, NV 89506

2. WELL LOCATION NE 1/4 SW 1/4 SEC. 24 T 21 R 18 E Washoe COUNTY

PERMIT NO ____ PARCEL NO 86-203-03 SUBDIVISION NAME Silver Knolls Ranchos

3. TYPE OF WORK
[ ] New Well [ ] Replace [ ] Recondition
[X] Deepen [ ] Plug [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [X] Mud

6. LITHOLOGIC LOG

MATERIAL	STRATA	FROM	TO	THICKNESS
D.G Green Clay		220	230	10
Blue & Green Clay, D.G.		230	250	20
Light Yellow & Gray Clay, Stickey		250	272	22
Sandy Dry Blue Clay		272	305	55
Thick Blue Clay & Sandy		305	360	55
Coarse Sands, Some Clay		360	390	30
Clay, Blue & Gray		390	400	10
Sands & Clay		400	458	58
Blue Green Gray Clay, Coarse Sand		458	493	35

2007 FEB -1 AM 11:16
STATE ENGINEER'S OFFICE

Notes: WGS-84 GPS: Latitude: N39 40.316 Longitude: W119 55.014
N 39.672046
W 119.915889 NAD27
N39.671955
W119.916519 NAD83

Date Started 01/09/2007 Date Completed 01/17/2007

7. WELL TEST DATA

TEST METHOD [ ] Bailer [ ] Pump [X] Air Develop

	GPM	DRAWDOWN	TIME (HRS)
	20+		.5

8. WELL CONSTRUCTION
Depth Drilled 493' Depth Cased 493'

HOLE DIAMETER (BIT SIZE)
7 7/8 Inches 220 Feet 458 Feet
6 1/4 Inches 458 Feet 493 Feet
Inches Feet Feet

CASING SCHEDULE

Size OD	Weight/Ft	Wall Thickness	From	To
6 5/8"	12.92	.188	178'	458'
5"	9.62	.188	433'	493'

PERFORATIONS:
Type Perforation Factory Size Perforation 3/32 x 3
From 358 Feet to 398 Feet
From 418 Feet to 438 Feet
From 453 Feet to 493 Feet

SURFACE SEAL: [X] Yes [ ] No
Seal Depth ____
PLACEMENT METHOD: [ ] Pumped [ ] Poured

SEAL TYPE:
[ ] Neat Cement
[ ] Cement Grout
[ ] Concrete Grout
[ ] Bentonite

GRAVEL PACKED: [ ] Yes [ ] No
From ____ Feet to ____ Feet

9. WATER LEVEL
Static Water Level 189 Feet Below Land Surface
Artesian Flow ____ GPM ____ PSI
Water Temperature Cool F Quality Clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of m knowledge.

Name Aqua Drilling & Well Service, Inc.
Address 675 Edison Way
Reno, NV 89502

NV. CONTRACTOR'S LIC. NO 15291 DRILLER'S LIC. NO. ON SITE 2189

Signed Roger M Thrall
By driller performing actual drilling on site or contractor

Dated January 31-2007