COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 102849
Permit No.
Basin 103

NOTICE OF INTENT NO. 58208

1. OWNER CLAUDE COUNCIL
MAILING ADDRESS 535 YELLOW JACKET
DAYTON, NV 89403

ADDRESS AT WELL LOCATION 27 ~~28~~ BALDWIN LN
CARSON CITY, N V89706

2. LOCATION ~~SW~~ SE ¼ ~~NE~~ SE ¼ Sec ~~28~~ 29 T 16 N R 21 E LYON County

PERMIT NO. | Issued by Water Resources | Parcel No. 016-212-03 | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SOFT POWER CLAY		0	3	3
BROWN CLAY		3	19	16
DG SANDS		19	87	68
FRACTURED GRANITE		87	135	48
MEDIUN GRANITE		135	176	41
BROWN CLAY		176	185	9
GRAY CLAY		185	207	22
SMALL GRANITE SANDS	XX	207	240	33

N 39.217273
W 119.639823 NAD27

Date started 2/12, 20 07
Date completed 2/16, 20 07

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
18	65	3 HRS

2007 MAR -6 AM 10:04

8. WELL CONSTRUCTION
Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 3/4	Inches	0	Feet	240	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	+2	20
6 5/8 sdr21	4.06	~~.216~~ .316	20	240

Perforations:
Type perforation SAW CUT
Size perforation 3 X 3/32
From 200 feet to 240 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 240 feet

Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

9. WATER LEVEL
Static water level 60 feet below land surface
Artesian flow G.P.M 18 P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING (CONTRACTOR)
Address 20 KIT KAT DRIVE (CONTRACTOR)
CARSON CITY, NV 89706
Nevada contractor's license number issued by the State Contractor's Board 0055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed [signature] By driller performing actual drilling on site or contractor
Date 2/24/07