WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 102860
Permit No.
Basin 162

NOTICE OF INTENT NO. 30200

1. OWNER Concordia Pleasant Valley - Monitor Well #2
MAILING ADDRESS 2630 E. Bridger
Pahrump, NV 89048

ADDRESS AT WELL LOCATION
2630 E. Bridger

2. LOCATION S/W 1/4 N/E 1/4 Sec. 13 T 21S N/S R 53E E Nye County
PERMIT NO. _____ Issued by Water Resources
44-561-22 Parcel No
Pleasant Valley Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
brown loam		0	8	8
See next line		8	24	16
brown loam with caleche strings				
grey caleche		24	29	5
brown caleche		29	52	23
brown clay	x	52	59	7
See next line	x	59	200	141
brown clay with caleche strings				

Date started 2/21/~~1997~~ 2007 , 19__
Date completed 3/9/~~1997~~ 2007 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200+5 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
7.5 inches	0 Feet	200 Feet
inches	Feet	Feet
inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2 1/2	.69	.154	0	200

Perforations:
Type perforation Factory Perf
Size perforation 0.020
From 50 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 200 feet

9. WATER LEVEL
Static water level 52 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Strickland Construction Co., Inc. Contractor
Address 5801 S. Homestead Contractor
Pahrump, NV 89048
Nevada contractor's license number issued by the State Contractor's Board 40277
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2066

Signed [signature] By driller performing actual drilling on-site or contractor
Date 3-12-07