WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 102861
Permit No.
Basin 162

NOTICE OF INTENT NO. 30199

1. OWNER Concordia Pleasant Valley - Monitor Well #1
MAILING ADDRESS 2631 E. Thousandaire
Pahrump, NV 89048

ADDRESS AT WELL LOCATION
2631 E. Thousandaire

2. LOCATION N/W 1/4 N/E 1/4 Sec. 13 T 21S N/S R 53E E Nye County
PERMIT NO. (Issued by Water Resources) 44-561-18 (Parcel No.) Pleasant Valley (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
brown loam		0	15	15
grey caleche		15	22	7
brown caleche	x	22	82	60
See next line	x	82	145	63
brown clay with caleche strings				
green clay	x	145	156	11
See next line	x	156	200	44
brown loam with caleche strings				

Date started 3/5/1907 2007, 19
Date completed 3/6/1907 2007, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200+5 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
7.5	Inches	0	Feet	200	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2 1/2	.69	.154	0	200

Perforations:
Type perforation Factory Perf
Size perforation 0.020
From 50 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 200 feet

9. WATER LEVEL
Static water level 52 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Strickland Construction Co., Inc. (Contractor)
Address 5801 S. Homestead (Contractor)
Pahrump, NV 89048
Nevada contractor's license number issued by the State Contractor's Board 40277
Nevada driller's license number issued by the Division of Water Resources, the onsite driller 2086
Signed (By driller performing actual drilling on site or contractor)
Date 3-12-07