WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 102868
Permit No.
Basin 162

NOTICE OF INTENT NO. 30508

1. OWNER DANIEL KATREEB
MAILING ADDRESS 481 E KENNY AVE
PAHRUMP, NV

ADDRESS AT WELL LOCATION 481 E KENNY AVE

2. LOCATION SE 1/4 SW 1/4 Sec. 15 T 19S N/S R 53E E NYE County
PERMIT NO. (Issued by Water Resources) 29-292-01 (Parcel No.) COUNTRY PLACE II UNIT 3 (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY CLAY	0	0	15	15
GRAVEL		15	24	9
CLAY		24	126	102
CALICHE	WB	126	128	2
CLAY		128	142	14
CALICHE	WB	142	151	9
CLAY		151	169	18
GRAVEL	WB	169	171	2
CLAY		171	194	23
GRAVEL	WB	194	220	26

WGS 84
N 36 DEGREES 17.663
W 116 DEGREES 00.360

8. WELL CONSTRUCTION
Depth Drilled 220 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	200	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	3.63	.250	0	2220

Perforations:
Type perforation SAWCUT
Size perforation 1/8 X 3
From 160 feet to 220 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 220 feet

9. WATER LEVEL
Static water level 78 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

Date started 5/9/2007 19
Date completed 5/9/2007 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO. OF NEVADA, INC. (Contractor)
Address 1220 E MANSE RD (Contractor)
PAHRUMP, NV. 89048
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed (Driller performing actual drilling on-site or contractor)
Date 5/15/2007

USE ADDITIONAL SHEETS IF NECESSARY