WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 102899
Permit No.
Basin 212

NOTICE OF INTENT NO. 30933

1. OWNER Jackie & Joe Pass
MAILING ADDRESS 62680 Deer Point Crt.
Las Vegas NV 89131

ADDRESS AT WELL LOCATION 6680 sly ~~62680~~ Deer Point Crt
Las Vegas, NV 89131

2. LOCATION NW ¼ SW ¼ Sec. 22 T. 19 N/S R. 60 E. Clark County

PERMIT NO. _____ Issued by Water Resources | 125-22-301-006 Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	2	2
Clay		2	30	28
Clay & Gravel		30	47	17
Gravel		47	76	29
Clay		76	112	36
Gravel	X	112	262	150
Caliche		262	331	69
Clay & Gravel		331	388	57
Sandstone		388	402	14
Gravel & Clay	X	402	420	18
36° 17' 12 N		Latitude		
115° 15' 29 W		Longitude		

Date started 5/11, 2007
Date completed 5/18, 2007

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
45		1

8. WELL CONSTRUCTION
Depth Drilled 420 Feet Depth Cased 420 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 7/8 Inches	0 Feet	420 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6			0	420

Perforations:
Type perforation Factory
Size perforation
From 320 feet to 420 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured

Seal Type:
☐ Neat Cement
☒ Cement Grout
☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 33 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name T.O.C. Water Wells (Contractor)
Address 2870 W. Pebble Rd. (Contractor)
Las Vegas, NV 89123

Nevada contractor's license number issued by the State Contractor's Board 59948

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2316

Signed [signature]
By driller performing actual drilling on site or contractor

Date 05-18-07

USE ADDITIONAL SHEETS IF NECESSARY