WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 102903
Permit No.
Basin 212

NOTICE OF INTENT NO. 30608

1. OWNER PATRICK WISNICKY
MAILING ADDRESS
ADDRESS AT WELL LOCATION NW CORNER OF CAMERO & MILLER

2. LOCATION SE ¼ NE ¼ Sec. 16 T. 22 S N/S R. 60 E. W CLARK County
PERMIT NO. 176-16-601-046
Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☑ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Cemented Gravel		0	175	
Gravel + Boulders		175	565	
Gravel + Boulders + Water		565	575	
Gravel + Boulders		575	765	
Gravel + Water	x	765	790	
Cemented Gravel		790	795	
Gravel + Water	x	795	805	

UCNR/DWR
RECEIVED
MAY 2 9 2007

N 36° 02 - 140'
W 115° 15 - 857'

ELEVATION - 2662

Date started 04-05-07, 20
Date completed 04-13-07, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 805 Feet Depth Cased 805 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12¼ Inches	0 Feet	50 Feet
9⅞ Inches	50 Feet	805 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	+2	50
6 1/2	PVC		+1	805

Perforations:
Type perforation Factory
Size perforation .032 Sieve Type
From 740 feet to 800 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50 FT
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☑ Concrete Grout

Gravel Packed: ☐ Yes ☑ No
From feet to feet

9. WATER LEVEL
Static water level 550 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name VERNON H. DIMICK
Contractor
Address 5360 N. BONITA VISTA ST
Contractor
LV, NV 89149
Nevada contractor's license number issued by the State Contractor's Board 10062
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552
Signed V H Dimick
By driller performing actual drilling on site or contractor
Date 04-30-07

(Rev. 12-02)

USE ADDITIONAL SHEETS IF NECESSARY