WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 102922
Permit No.
Basin 203

NOTICE OF INTENT NO. 30697

1. OWNER BEAU CARLSON
MAILING ADDRESS P.O. BOX 413
PAHRUMP NV 89042

ADDRESS AT WELL LOCATION #40 HIGHLAND KNOLLS
CALIENTE NV 89008

2. LOCATION SW ¼ NW ¼ Sec. 3 T. 3-S N/S R. 67 E E/W LINCOLN County
PERMIT NO. (Issued by Water Resources) 013-042-06 (Parcel No) HIGHLAND KNOLLS (Subdivision Name)

3. WORK PERFORMED: ☑ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE: ☑ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE: ☐ Cable ☑ Rotary ☐ RVC ☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND - BOULDERS		0	18	18
HARD SANDSTONE		18	20	2
GRAVEL & BOULDERS		20	38	18
HARD SANDSTONE		38	44	6
BROWN SANDY CLAY		44	104	60
1/4" GRAVEL		104	110	6
BROWN SANDY CLAY		110	122	12
RED SANDY CLAY		122	170	48
GRAVEL		170	182	12
RED CLAY		182	190	8
GRAVEL	YES	190	223	33
RED CLAY		223	230	7
GRAVEL	YES	230	255	25
RED SANDY CLAY		255	260	5

Date started 03-14-2007, 19
Date completed 05-21-2007, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☑ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15	24	1.5

8. WELL CONSTRUCTION
Depth Drilled 260 Feet Depth Cased 260 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
9 7/8	0	60
7 7/8	60	260

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5"	SCH-40	SDR 20	+1	260

Perforations:
Type perforation VERTICAL
Size perforation 1/8" X 6" x 4 ROWS
From 220 feet to 260 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☑ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 50' feet to 260 feet

9. WATER LEVEL
Static water level 181 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 63 °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name RCBR INC (Contractor)
Address 6411 W. DEERSPRING WAY (Contractor)
LAS VEGAS NV 89131
Nevada contractor's license number issued by the State Contractor's Board 0020301
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2064
Signed (By driller performing actual drilling on site or contractor)
Date 05-22-07

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY 101-427