WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
# DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 102925
Permit No.
Basin 162

NOTICE OF INTENT NO. 30518

1. OWNER KATHLEEN DILLMAN
MAILING ADDRESS 6260 S OAKRIDGE AVE
PAHRUMP, NV

ADDRESS AT WELL LOCATION 6260 S OAKRIDGE AVE

2. LOCATION NE 1/4 NW 1/4 Sec. 13 T 21S N/S R 53E E NYE County
PERMIT NO. Issued by Water Resources
44-692-04 Parcel No.
CONESTOGA COUNTRY ESTATES Subdivision Name

3. WORK PERFORMED
New Well | Replace | Recondition
X Deepen | Abandon | Other

4. PROPOSED USE
X Domestic | Irrigation | Test | Cable
Municipal/Industrial | Monitor | Stock | X Air | Other

5. WELL TYPE
X Rotary | RVC

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| EXISTING 8" WELL | | 0 | 140 | 140 |
| CLAY | | 140 | 150 | 10 |
| CALICHE | WB | 150 | 175 | 25 |
| CLAY | | 175 | 195 | 20 |
| CALICHE | WB | 195 | 215 | 20 |
| CLAY | | 215 | 223 | 8 |
| CALICHE | WB | 223 | 240 | 17 |

WGS 84
N36 DEGREES 07.706
W 115 DEGREES 58.014

8. WELL CONSTRUCTION
Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | | To | |
|---|---|---|---|---|---|
| EXISTING | Inches | 0 | Feet | 140 | Feet |
| 7 7/8 | Inches | 140 | Feet | 240 | Feet |
| | Inches | | Feet | | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| EXISTING 8 | | | 0 | 140 |
| 4.5 | 2.36 | .248 | 0 | 240 |

Perforations:
Type perforation SAWCUT
Size perforation 1/8 X 3
From 140 feet to 240 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: X Yes No
Depth of Seal EXISTING
Placement Method: Pumped
X Poured

Seal Type:
Neat Cement
Cement Grout
X Concrete Grout

Gravel Packed: X Yes No
From 50 feet to 240 feet

9. WATER LEVEL
Static water level 81 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

Date started 5/1/2007 '9
Date completed 5/1/2007 '9

7. WELL TEST DATA
TEST METHOD: Bailer | Pump | Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO. OF NEVADA, INC. Contractor
Address 1220 E MANSE RD Contractor
PAHRUMP, NV. 89048
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1426
Signed By driller performing actual drilling on site or contractor
Date 5/1/2007

USE ADDITIONAL SHEETS IF NECESSARY