COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 102972
Permit No.
Basin 162

NOTICE OF INTENT NO. 30581

1. OWNER **Freedom Homes**
MAILING ADDRESS
ADDRESS AT WELL LOCATION **2730 E. Dandelion St.**

2. LOCATION **SW** ¼ **SE** ¼ Sec **25** T **20-S** N R **53** E **Nye** County
PERMIT NO. (Issued by Water Resources) **42-563-16** (Parcel No.) **Calvada Valley Unit 2; Blk 25; Lot 9** (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Loam		**0**	**36**	**36**
Brown Clay/Caliche		**36**	**73**	**37**
Limestone		**73**	**84**	**11**
Brown Clay/Caliche	**X**	**84**	**200**	**116**

Location:
N 36° 10.569'
W 115° 57.847'

Elevation: 2654'
Accuracy: 20'

Date started **June 14**, 20 **07**
Date completed **June 14**, 20 **07**

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION

Depth Drilled **200** Feet Depth Cased **200** Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	**0** Feet	**200** Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	**3.92**	**.28**	**0**	**200**

Perforations:
Type perforation **Saw Cut**
Size perforation **1/4" width 8" long**
From **160** feet to **200** feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal **50'** ☐ Neat Cement
Placement Method: ☐ Pumped ☐ Cement Grout
☒ Poured ☒ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From **50** feet to **200** feet

9. WATER LEVEL
Static water level **84** feet below land surface
Artesian flow G.P.M P.S.I
Water temperature **Cold** °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name **JIM PIKE WELL DRILLING, LLC.** (CONTRACTOR)
Address **P.O. BOX 56** (CONTRACTOR)
PAHRUMP, NV 89041
Nevada contractor's license number issued by the State Contractor's Board **17563A**
Nevada driller's license number issued by the Division of Water Resources, ~~the on-site~~ driller **1324**
Signed
By driller performing actual drilling on site or contractor
Date **June 15, 2007**

USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk, Inc. · (214) 340-9429 · FormsOnADisk.com