

COPIES TO  
 - DIVISION OF WATER RESOURCES  
 - CLIENT'S COPY  
 - WELL DRILLER'S COPY

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY  
 Log No. 103037  
 Permit No. \_\_\_\_\_  
 Basin 162  
 NOTICE OF INTENT NO. 30584

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

PRINT OR TYPE ONLY

1. OWNER Ron Holt  
 MAILING ADDRESS \_\_\_\_\_  
 ADDRESS AT WELL LOCATION 821 W. White Rd.

2. LOCATION SW 1/4 NW 1/4 Sec 9 T 20-S N R 53 E Nye County  
 PERMIT NO. 35-171-07 Cal-Vegas Ranchos Unit D; Lot 214

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Surface		0	4	4
Brown Clay		4	8	4
Brown Clay/Caliche		8	53	45
Brown Clay		53	61	8
Brown Clay/Caliche	X	61	116	55
Brown Clay	X	116	122	6
Brown Clay/Caliche	X	122	180	58

Location:  
N 36° 13.748'  
W 116° 01.783'

Elevation: 2579'  
 Accuracy: 16'

8. WELL CONSTRUCTION  
 Depth Drilled 180 Feet Depth Cased 180 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From \_\_\_\_\_ To \_\_\_\_\_  
10 Inches \_\_\_\_\_ 0 Feet \_\_\_\_\_ 180 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>3.92</u>	<u>.28</u>	<u>0</u>	<u>180</u>

Perforations:  
 Type perforation Saw Cut  
 Size perforation 1/4" width 8" long  
 From \_\_\_\_\_ 140 feet to \_\_\_\_\_ 180 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ 50 feet to \_\_\_\_\_ 180 feet

9. WATER LEVEL  
 Static water level \_\_\_\_\_ 52 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ Cold °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name JIM PIKE WELL DRILLING, LLC.  
 (CONTRACTOR)  
 Address P.O. BOX 56  
 (CONTRACTOR)  
PAHRUMP, NV 89041  
 Nevada contractor's license number issued by the State Contractor's Board 17563A  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1324  
 Signed Jim Pike  
 By driller performing actual drilling on site or contractor  
 Date July 5, 2007

Date started July 2, 20 07  
 Date completed July 2, 20 07

7. WELL TEST DATE

TEST METHOD:	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift		
G.P.M.		

JUL 09 2007  
 LAB WELLS OFFICE