COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 703051
Permit No.
Basin 105

NOTICE OF INTENT NO. 58237

1. OWNER LARRY SILVERIA CONSTRUCTION
MAILING ADDRESS 2447 MT COMO
GARDNERVILLE, NV 89410
ADDRESS AT WELL LOCATION 929 BAR J
GARDNERVILLE, NV 89410

2. LOCATION ~~NW~~ SW ¼ ~~SW~~ NW ¼ Sec 15 T 12 N R 21 E DOUGLAS County
PERMIT NO. Issued by Water Resources
1221-15-000-009 Parcel No.
Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BROWN CLAY SMALL GRAVELS		0	46	46
BROWN CLAY		46	258	212
GRAY CLAY GUMMY		258	392	134
GRAY CLAY W/ SOFT SANDY AREAS	X	392	440	48
GRAY CLAY		440	449	9
FRACTURED GRAVELS	XXX	449	500	51

N 38.905168
W 119.619028 NAD27

GPS INFO: NAD 83
38.90507*N
119.62002*W

Date started 1/2, 20 07
Date completed 1/19, 20 07

7. WELL TEST DATE
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
18	125	3 HRS

8. WELL CONSTRUCTION
Depth Drilled 500 Feet Depth Cased 500 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
11 Inches	0 Feet	260 Feet
9 7/8 Inches	260 Feet	440 Feet
6 1/8 Inches	440 Feet	500 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	1303	.188	+2	440
5"	11.78	.188	435	500

Perforations:
Type perforation FACTORY MILL SLOT
Size perforation 3 X 3/32
From 380 feet to 400 feet
From 420 feet to 440 feet
From 480 feet to 500 feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 60 ☐ Neat Cement
Placement Method: ☐ Pumped ☒ Cement Grout
☒ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 60 feet to 440 feet

9. WATER LEVEL
Static water level 193 feet below land surface
Artesian flow G.P.M P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING (CONTRACTOR)
Address 20 KIT KAT DRIVE (CONTRACTOR)
CARSON CITY, NV 89706
Nevada contractor's license number issued by the State Contractor's Board 0055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2157
Signed Rick Crane
By driller performing actual drilling on site or contractor
Date 1/24/07

(Rev 3-91) USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk, Inc. · Dallas, Texas · (214) 340-9429