


STATE OF NEVADA
 DIVISION OF WATER RESOURCES
 WELL DRILLER'S REPORT



OFFICE USE ONLY

Log No. 103068

Permit No. _____

Basin 073A

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 59479

1. OWNER Wayne & Georgia Morgan ADDRESS AT WELL LOCATION 21720 Pyramid Lake Road Lovelock, NV 89419
 MAILING ADDRESS 11575 Rye Patch Res.

Subdivision Name: Humboldt River Ranch County: Pershing

2. LOCATION S6 1/4 SW 1/4 Sec 16 T30N R33E Latitude N40°28.089' UTM E NAD 27

PERMIT/WAIVER NO. _____ Parcel No. _____ Longitude W118°16.591' N NAD 83/WGS 84

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
sand cobbles		0	2	2
clay		2	3	1
gravel & cobbles		3	15	12
3/4 gravel		15	50	35
clay		60	62	2
course gravel ledge		62	100	38
cobbles & gravel		100	110	10
gravel w/clay fingers		110	130	20
course sand & gravel	X	130	160	30
		160	180	20

2007 MAR -1 AM 10:55
 STATE ENGINEER'S OFFICE

N 40.168260
 W 118.275540 NAD27

Date started: February 23, 20 07
 Date completed: February 26, 20 07

9. WELL CONSTRUCTION

Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)

From _____ To _____

10 5/8 Inches 0 Feet 180 Feet

_____ Inches _____ Feet _____ Feet

_____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>10</u>	<u>188</u>	<u>+1</u>	<u>20</u>
<u>6.625</u>	<u>4.06</u>	<u>.316</u>	<u>20</u>	<u>160</u>

Perforations:
 Type of perforation Factory Cut slot
 Size of perforation 050

From 160 feet to 180 feet

From _____ feet to _____ feet

Annular Seal: Yes No

Neat Cement _____ to _____ Pumped Poured

Cement Grout _____ to _____ Pumped Poured

Concrete Grout _____ to _____ Pumped Poured

≥30% Bentonite Grout _____ to _____ Pumped Poured

Gravel Pack: Yes No 50 to 180 Pumped Poured

Type: _____

Bentonite Chips: Yes No _____ to _____ Pumped Poured

Type: _____

7. Water Level

Static water level: 64' feet below land surface

Artesian Flow: N/A G.P.M. N/A P.S.I.

Water Temperature: cool °F

Quality: fair

8. WELL TEST DATA

TEST METHOD:	□ Bailer	□ Pump	<input checked="" type="checkbox"/> Air Lift
G.P.M.	Draw Down (Feet Below Static)		Time (Hours)
<u>20</u>			<u>4</u>

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Fred Anderson Drilling, Inc.
 (CONTRACTOR)

Address 10760 S. Grass Valley Road
 (CONTRACTOR)

Winnemucca, Nv 89445

Nevada contractor's license number issued by the State Contractor's Board 21467

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2083

Signed Fred Anderson Drilling, Inc.
 By driller performing actual drilling on site or contractor

Date February 27, 2007