COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 103225
Permit No.
Basin 212

NOTICE OF INTENT NO. 31350

1. OWNER FOUNTAINEBLEAU LAS VEGAS LLC
MAILING ADDRESS 2827 PARADISE RD
LAS VEGAS, NV 89109

ADDRESS AT WELL LOCATION 2755 S. LAS VEGAS BLVD.
LAS VEGAS, NV

2. LOCATION SE ¼ NE ¼ Sec 09 T 21 S R 61 E CLARK County

PERMIT NO. DW1233A (Issued by Water Resources) | 162-09-602-002 (Parcel No.) | Fontainebleau (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE DEWATER
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
9- Dewater wells				
Depth 50'				
Brown dirt & rock		0	14'	14'
Moist dirt & rock	x	14'	17'	3'
White silty clay		17'	19'	2'
Brown silty clay		19'	32'	13'
Caliche		32'	34'	2'
Brown clay		34'	42'	8'
Caliche		42'	43'	1'
Tan clay & silt		43'	50'	7'

WG-584
N36° 08. 182'
W115° 09. 555'

DCNR/DWR
RECEIVED
AUG 29 2007
LAS VEGAS OFFICE

Date started 8/13, 20 07
Date completed 8/15, 20 07

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION

Depth Drilled 50 Feet Depth Cased 50 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
24 Inches	0 Feet	50 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation Machine
Size perforation 1/4"x2.5" long 16 around
From 30 feet to 50 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No Seal Type:
Depth of Seal ☐ Neat Cement
Placement Method: ☐ Pumped ☐ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 0 feet to 50 feet

9. WATER LEVEL
Static water level 15 feet below land surface
Artesian flow G.P.M P.S.I
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ALLEN DRILLING INC. (CONTRACTOR)
Address 4015 WEST TOMPKINS AVE (CONTRACTOR)
LAS VEGAS, NV 89103
Nevada contractor's license number issued by the State Contractor's Board 18916 & 18917
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2231
Signed
By driller performing actual drilling on site or contractor
Date August 23, 2007

Forms Provided by Forms-On-A-Disk, Inc. · (214) 340-9429 · FormsOnADisk.com