

CU VVWJ

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 103263
Permit No.
Basin 212

NOTICE OF INTENT NO. 26717

1. OWNER DIAMOND CONST. CO. ADDRESS AT WELL LOCATION 4890 S. HOLLYWOOD BLVD
 MAILING ADDRESS 1140 WIGWAM PARKWAY LAS VEGAS 89122
HENDERSON, NV 89074-815A
 2. LOCATION NE 1/4 SW 1/4 Sec. 23 T. 21 N. R. 62 E. CLARK County
 PERMIT NO. 1314A Issued by Water Resources Parcel No. 161-23-301-002 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. Dewater PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other BUCKET

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND & GRAVEL		0	12	12
CLAY W/ FEW SAND LENSES & CALICHE LENSES	✓	12	37	25

DEWATERING RECEIVED
JUL 19 2007
LAS VEGAS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 37 Feet Depth Cased 37 Feet
 HOLE DIAMETER (BIT SIZE)
 From 36 Inches To 37 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	22.3	.250	0	17

Perforations:
 Type perforation LOUVERED
 Size perforation .050
 From 17 feet to 37 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal _____
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 0 feet to 37 feet

9. WATER LEVEL
 Static water level 16 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started JUNE 14, 2007 19____
 Date completed JUNE 26, 2007 19____

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift		
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
4	25	5 MIN.

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name KELLEY DEWATERING Contractor
 Address 5175 CLAY Contractor
WYOMING, W.I. 49458
 Nevada contractor's license number issued by the State Contractor's Board 50826
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller ABDS 2149
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 7-10-07