CU WELLS

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 103265
Permit No.
Basin 212

NOTICE OF INTENT NO. 26717

1. OWNER DIAMOND CONST. CO.
MAILING ADDRESS 1140 WIGWAM PARKWAY
HENDERSON, NV 89074-8154

ADDRESS AT WELL LOCATION
4890 S. HOLLYWOOD BLVD
LAS VEGAS 89122

2. LOCATION NE ¼ SW ¼ Sec. 23 T. 21 N/S R. 62 E. CLARK County
PERMIT NO. 1314A (Issued by Water Resources) 161-23-301-002 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ DEWATER
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other BUCKET

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| SAND & GRAVEL | | 0 | 12 | 12 |
| CLAY W/ FEW SAND LENSES & CALICHE LENSES | ✓ | 12 | 37 | 25 |

RECEIVED
JUL 12 2007
LAS VEGAS OFFICE

Date started JUNE 14, 2007, 19
Date completed JUNE 26, 2007, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 4 | 25 | 5 MIN. |

8. WELL CONSTRUCTION
Depth Drilled 37 Feet Depth Cased 37 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 36 Inches | | 0 Feet | 37 Feet |
| Inches | | Feet | Feet |
| Inches | | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 8 | 22.3 | .250 | 0 | 17 |

Perforations:
Type perforation LOUVERED
Size perforation .050
From 17 feet to 37 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☑ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 0 feet to 37 feet

9. WATER LEVEL
Static water level 16 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name KELLEY DEWATERING (Contractor)
Address 5175 CLAY (Contractor)
WYOMING, MI. 49458
Nevada contractor's license number issued by the State Contractor's Board 50826
Nevada driller's license number issued by the Division of Water Resources, the on-site driller ABDS 2149
Signed (By driller performing actual drilling on site or contractor)
Date 7-10-07

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627