STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 103333
Permit No.
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 31425

1. OWNER Clark County Aviation
MAILING ADDRESS P.O. Box 11005
Las Vegas, Nv

ADDRESS AT WELL LOCATION McCarren Airport Terminal 3
5757 Wanye Newton Boulevard, Las Vegas, NV
Subdivision Name: County: CLARK

2. LOCATION NW¼ NW ¼ Sec 35 T 21 S R 61 E
PERMIT/WAIVER No. DW-1244A (Issued by Water Resources) 162-35-101-018 (Parcel No.)
Latitude Longitude UTM E N NAD 27 x NAD 83/WGS 84

3. WORKED PERFORMED
X New Well, Replace, Recondition, Deepen, x Other Dewatering Well

4. PROPOSED USE Dewater
Domestic, Irrigation, Test, Municipal/Industrial, ~~X Monitor~~, Stock

5. WELL TYPE
Cable, Rotary, RVC, Air, x Other, Auger Bucket

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Well # 7440				
N486443.5 E632370.7				
Fill - gravelly clay		0	8	8
Sandy lean clay		8	16	8
Caliche - hard off white		16	18	2
Sandy lean clay		18	25	7
Fat Clay - w/gravels		25	48	23
Caliche - hard off white		48	52	4
Fat Clay - w/gravels partially cem		52	61	9

Date started: 27-Jun, 20 07
Date completed: 6/27/2007, 20 07

9. WELL CONSTRUCTION
Depth Drilled 61' Feet Depth Cased 60' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
24"	0	50
24" Inches	surface Feet	61' Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.5	3.6	.280	0	30

Perforations:
Type of perforation machine slot
Size of perforation .032"
From 30 feet to 60 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: Yes X No
Neat Cement to Pumped Poured
Cement Grout to Pumped Poured
Concrete Grout to Pumped Poured
≥30% Bentonite Grout to Pumped Poured
Gravel Pack: X Yes No 0 50 Pumped X Poured
Type: pea gravel
Bentonite Chips: Yes X No to Pumped Poured
Type:

7. Water Level
Static water level: 31 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: Bailer x Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Griffin Dewatering Corp (Contractor)
Address 536 E. Maitland Street (Contractor)
Ontario, Ca 91761
Nevada contractor's license number issued by the *State Contractor's Board* C-23 0031246
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* M-2264
Signed [signature] (By driller performing actual drilling on site or contractor)
Date July 9, 2007

LAS [illegible] OFFICE