

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 30954

1. OWNER City of Las Vegas Public Works ADDRESS AT WELL LOCATION LAS VEGAS BLVD
 MAILING ADDRESS 731 South Earth St. at Main - SW
Las Vegas, NV. 89101

2. LOCATION SW 1/4 NW 1/4 Sec. 3 T. 21 N. R. 61 E Clark County
 PERMIT NO. 162-03-299-029 Parcel No. N. 36.153802 Subdivision Name W. 115.150846 (WGS 84)

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Fill - Sandy Clay</u>		<u>0</u>	<u>2</u>	<u>2</u>
<u>CL - Silty Clay</u>		<u>2</u>	<u>9 1/2</u>	<u>7 1/2</u>
<u>Caliche</u>		<u>9 1/2</u>	<u>14 1/2</u>	<u>5</u>
<u>SM - Silty Sand</u>	<u>Wat</u>	<u>14 1/2</u>	<u>16</u>	<u>1 1/2</u>
<u>LL - Silty Clay</u>		<u>16</u>	<u>25</u>	<u>9</u>

8. WELL CONSTRUCTION
 Depth Drilled 25 Feet Depth Cased 25 Feet
 HOLE DIAMETER (BIT SIZE)
 From 8 Inches To 0 Feet
0 Feet 25 Feet
 _____ Feet _____ Feet
 _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4"</u>	<u>Sch. 40</u>	<u>ASTM F480</u>	<u>0</u>	<u>25</u>

Perforations:
 Type perforation FOZO Factory Slots
 Size perforation 020
 From 5 feet to 25 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 4 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 4 feet to 25 feet

9. WATER LEVEL
 Static water level 15 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 66.1 °F Quality _____

Date started 5-18, 2007
 Date completed 5-25, 2007

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift		
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>NA</u>		

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Elite Drilling Inc. Contractor
 Address 4255 W. Post Rd. Contractor
Las Vegas, NV. 89118
 Nevada contractor's license number issued by the State Contractor's Board _____
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1944
 Signed Thomas M. Beall
 By driller performing actual drilling on site or contractor
 Date 5-29-07