

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO 31003

1. OWNER U.S.A (BLM) ADDRESS AT WELL LOCATION Nelson, Nevada  
 MAILING ADDRESS Washington DC  
 2. LOCATION NE NW 1/4 NE 1/4 Sec. 10 T 26 N R 64 E Clark County  
 PERMIT NO. 60369 228-10-501006  
 Issued by Water Resources Parcel No. Subdivided Name 08B

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE Mining  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Abandoned 8" well to 141' Depth. No system in well but well full of debris. Drilled out Debris from well, hit water at 17 feet. drilled out rocks, cedar boards and debris until 141' feet. then hit virgin material.				
Perforated casing with mill knife perforator from 141' to the top of the well. Pumped in 6 yards of neat cement through a tremmie hose from the bottom of the well to the surface, completely filling the well.				
Plugging of log # 164306				
GPS NAD 83 35-704 570 N 114-817 300 W				

8. WELL CONSTRUCTION  
 Depth Drilled 141' Feet Depth Cased \_\_\_\_\_ Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 8 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8</u>				

Perforations:  
 Type perforation \_\_\_\_\_  
 Size perforation \_\_\_\_\_  
 From \_\_\_\_\_ feet to 141 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal \_\_\_\_\_  Neat Cement  
 Cement Grout  
 Placement Method:  Pumped  Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 8/20/07  
 Date completed 8/22/07

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
	<u>0.5</u>	

RECEIVED  
 AUG 31 2007  
 LAS VEGAS OFFICE

9. WATER LEVEL  
 Static water level 17' feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name T.D.C. Drilling Contractor  
 Address 2870 W Pebble Rd Contractor  
Las Vegas NV 89123  
 Nevada contractor's license number issued by the State Contractor's Board 59948  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2316  
 Signed R R B  
 By driller performing actual drilling on site or contractor  
 Date 8/29/07