



STATE OF NEVADA DIVISION OF WATER RESOURCES WELL DRILLER'S REPORT		OFFICE USE ONLY	
		Log No.	103519
		Permit No.	212
Basin		212	
PRINT OR TYPE ONLY		Please complete this form in its entirety in	
DO NOT WRITE ON BACK		accordance with NRS 534.170 and NAC 534.340	
NOTICE OF INTENT NO.			31424
1. OWNER Clark County Aviation		ADDRESS AT WELL LOCATION McCarran Airport Terminal 3	
MAILING ADDRESS P.O. Box 11005 Las Vegas, Nv		5757 Wayne Newton Boulevard, Las Vegas, NV	
Subdivision Name:		County:	
2. LOCATION NE 1/4 NE 1/4 Sec 34 T 21 N/S R 61 E		Latitude UTM E NAD 27	
PERMIT/WAIVER No. DW-1243A 162-34-502-010		Longitude N x NAD 83/WGS 84	
Issued by Water Resources		Parcel No. 162-35-101-018	
3. WORKED PERFORMED		4. PROPOSED USE DEWATER	
5. WELL TYPE			
New Well	Replace	Recondition	Domestic
Deepen	x Other	Dewatering Well	Municipal/Industrial
Irrigation	Test	Cable	Rotary
Monitor	Stock	Air	x Other
Auger Bucket			
6. LITHOLOGIC LOG		9. WELL CONSTRUCTION	
Material	Water Strata	From	To
Thick-ness			
Well #7407		Depth Drilled 51' Feet	
N486875.8 E631710.9		Depth Cased 50' Feet	
Clayey Gravel		HOLE DIAMETER (BIT SIZE)	
Caliche - white/hard		24" From 0 To 50	
Fat Clay-with sand, gravel		24" Inches surface Feet 50' BGL Feet	
Silty Clayey Sand - red,brown		Inches Feet Feet	
Clayey Gravel, cemented lenses		Inches Feet Feet	
Sandy Fat Clay, brown to tan		CASING SCHEDULE	
Caliche - moderate cemented		Size O.D. Weight/Ft. Wall Thickness From To	
Caliche - hard		(Inches) (Pounds) (Inches) (Feet) (Feet)	
		6.5 3.6 .280 0 20	
		Perforations:	
		Type of perforation machine slot	
		Size of perforation .032"	
		From 20 feet to 50 feet	
		From feet to feet	
		From feet to feet	
		From feet to feet	
		From feet to feet	
		Annular Seal: Yes X No	
		Neat Cement to Pumped Poured	
		Cement Grout to Pumped Poured	
		Concrete Grout to Pumped Poured	
		≥30% Bentonite Grout to Pumped Poured	
		Gravel Pack: X Yes No 0 50 Pumped X Poured	
		Type: pea gravel	
		Bentonite Chips: Yes X No to Pumped Poured	
		Type:	
Date started: 17-Jul 20 07			
Date completed: 7/17/2007 20 07			
7. Water Level		10. DRILLER'S CERTIFICATION	
Static water level: 26' feet below land surface		This well was drilled under my supervision and the report is true to the best of my knowledge.	
Artesian Flow: G.P.M. P.S.I.		Name Griffin Dewatering Corp	
Water Temperature: °F		Contractor	
Quality:		Address 536 E. Maitland Street	
8. WELL TEST DATA		Contractor	
TEST METHOD: Bailer Pump Air Lift		Ontario, Ca 91761	
G.P.M. Draw Down Time (Hours)		Nevada contractor's license number	
(Feet Below Static)		issued by the State Contractor's Board C-23 0031246	
		Nevada driller's license number issued by the	
		Division of Water Resources, the on-site driller M-2264	
		Signed <i>[Signature]</i> DENR/DWR	
		By driller performing actual drilling on site of contractor RECEIVED	
		Date 7/31/06	

(Rev. 05-00)

USE ADDITIONAL SHEETS IF NECESSARY

AUG 03 2007