

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

4 weeks

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 31455

1. OWNER BP WEST AMT PRODUCTS
MAILING ADDRESS PO Box 5015
Boena Park CA
ADDRESS AT WELL LOCATION
2873 S. LAS VEGAS BLVD
LAS VEGAS NV.
2. LOCATION SW 1/4 NW 1/4 Sec. 28 T. 21
PERMIT NO. 162-28-201-001 N^oR. 61 E CLARK County
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other R/S/H

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>ASPHALT</u>		<u>0.0</u>	<u>0.4</u>	<u>0.4</u>
<u>SAND & GRAVEL</u>		<u>0.4</u>	<u>6.0</u>	<u>5.6</u>
<u>SILTY SAND</u>		<u>6.0</u>	<u>7.0</u>	<u>1.0</u>
<u>SAND & GRAVEL</u>		<u>7.0</u>	<u>23.0</u>	<u>16.0</u>
<u>CLAY</u>		<u>23.0</u>	<u>29.0</u>	<u>6.0</u>
<u>GRAVEL w/SAND</u>		<u>29.0</u>	<u>32.5</u>	<u>3.5</u>

MAP DATUM WGS 84
w-3 36° 05' 824 N 115° 10' 331 W
w-2 36° 05' 830 N 115° 10' 353 W
w-7 36° 05' 831 N 115° 10' 322 W
w-6 36° 05' 820 N 115° 10' 346 W

8. WELL CONSTRUCTION
Depth Drilled 30/32.5/32 Feet Depth Cased 30/32.5/32 Feet
HOLE DIAMETER (BIT SIZE)
From To
1 1/2 Inches 0.0 Feet 30.0 Feet
1 1/2 Inches 0.0 Feet 32.5 Feet
1 1/2 Inches 0.0 Feet 32.0 Feet
CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4.25</u>		<u>SC40 PVC</u>	<u>0.0</u>	<u>30.0</u>
<u>4.25</u>		<u>SC40 PVC</u>	<u>0.0</u>	<u>32.5</u>
<u>4.25</u>		<u>SC40 PVC</u>	<u>0.0</u>	<u>32.0</u>

Perforations:
Type perforation MACHINE SLOT
Size perforation 2 020
From 30.0 feet to 15.0 feet
From 32.5 feet to 17.5 feet
From 32.0 feet to 12.0 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
Surface Seal: Yes No Seal Type:
Depth of Seal 15'/19.5'/12' Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From 30/32.5/32 feet to 13/15.5/10 feet

9. WATER LEVEL
Static water level 23 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ERABO DRILLING SERVICES LLC Contractor
Address 7150 PLACID ST. Contractor
LAS VEGAS NV. 89119
Nevada contractor's license number issued by the State Contractor's Board 51266
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M.2272
Signed [Signature]
By driller performing actual drilling on site or contractor
Date 7/30/07

7. WELL TEST DATA
TEST METHOD: Bailer Pump Air Lift
G.P.M. Draw Down (Feet Below Static) Time (Hours)

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

Date started 7/22/07
Date completed 7/10/07

DCNR/DWR
RECEIVED
AUG 01 2007
LAS VEGAS OFFICE