COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 103587
Permit No.
Basin 106

NOTICE OF INTENT NO. 60302

1. OWNER DALE ARMSTRONG
MAILING ADDRESS P.O. BOX 218 Gardnerville NV 89410
ADDRESS AT WELL LOCATION 1526 BOLTON LOOP GRDNERVILLE, NV 89410

2. LOCATION ~~SE~~ ¼ ~~SW~~ ¼ Sec 18 T 10 N R 22 E DOUGLAS County
PERMIT NO. SW SE (Issued by Water Resources) | 1022-18-002-067 (Parcel No.) | HOLBROOK JUNCTION (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OVRBURDEN		0	3	3
BROWN CLAY		3	18	15
DG SSANDS		18	73	55
BROWN CLAY		73	126	63
SMALL SILTY SANDS		126	192	66
FRACTURED VOLCAN. GRAVELS	X	192	220	28
COURSE GRAVELS	XX	220	260	40

N34.726004
W 119.560132 NAD27

GPS INFO: NAD 83
38.072591*N
119.56112*W

Date started 8/4, 20 07
Date completed 8/6, 20 07

7. WELL TEST DATE
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15	65	3 HRS

8. WELL CONSTRUCTION
Depth Drilled 260' Feet Depth Cased 260' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	220 Feet
6 1/8 Inches	220 Feet	260 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	+2	20
6 5/8 dr 21	4.03	.216	20	220
5	11.62	.188	215	260

Perforations:
Type perforation SAW CUT
Size perforation 3 X 3/32
From 180 feet to 220 feet
From 220 feet to 260 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 100 ☐ Neat Cement
Placement Method: ☐ Pumped ☒ Cement Grout
☒ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 100 feet to 260 feet

9. WATER LEVEL
Static water level 75 feet below land surface
Artesian flow G.P.M P.S.I
Water temperature COLD °F Quality OOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING (CONTRACTOR)
Address 20 KIT KAT DRIVE (CONTRACTOR)
CARSON CITY, NV 89706
Nevada contractor's license number issued by the State Contractor's Board 0055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed Michael Hack
By driller performing actual drilling on site or contractor
Date 8/9/07

STATE ENGINEER'S OFFICE 2007 AUG 14 AM 9:55