



Log No. 103638
 Permit No. _____
 Basin 100

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 52996

1. OWNER Joan Shadler ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 11355 Deadwood Dr. Reno NV 89506 11385 Deadwood Dr. Reno NV 89506
 2. LOCATION 1/4 NE 1/4 Sec. 24 T. 21 S. R. 18 E. Washoe County _____
 PERMIT NO. 086-232-44 Parcel No. _____ Subdivision Name Silver Knolls
 Issued by Water Resources _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other msd

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fill dirt		0	2	2
Packed Sand		2	17	15
Sand		17	40	23
Clay		40	60	20
Sand		60	80	20
Clay Sand layer		80	100	20
Sand		100	126	26
Clay		126	136	10
Sand		136	156	20
Clay		156	224	68
Sand		224	258	34
Clay		258	360	102
Sand		360	390	30
Clay		390	400	10

N 39.67558
 W 119.911221 NAD 87

8. WELL CONSTRUCTION
 Depth Drilled 404 Feet Depth Cased 400 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 400 Feet
 _____ Inches _____ Feet
 _____ Inches _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.9</u>	<u>3/16</u>	<u>0</u>	<u>400</u>

 Perforations:
 Type perforation Saw Slot
 Size perforation 3/16
 From 220 feet to 260 feet
 From 360 feet to 400 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal 50 Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From 50 feet to 400 feet

9. WATER LEVEL
 Static water level 140 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 2/15, 2007
 Date completed 3/25/, 2007

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>40</u>	<u>400</u>	<u>1:11:00</u>

RECEIVED
 2007 APR 20 AM 11:00

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Olenzki Drilling Contractor
 Address 15045 Red Rock Rd Reno NV 89506 Contractor
 Nevada contractor's license number 50343 issued by the State Contractor's Board.
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1656
 Signed John F. Olenzki
 By driller performing actual drilling on site or contractor
 Date 4/1/07