WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 103651
Permit No.
Basin 108

NOTICE OF INTENT NO. 58657

1. OWNER City of Yerington
MAILING ADDRESS 102 South Main St.
Yerington, NV 89447

ADDRESS AT WELL LOCATION ~~NW~~ 95 Mountain Street

2. LOCATION NW 1/4 SE 1/4 Sec. 15 T 13N N/S R 25E E Lyon County
PERMIT NO. 65296, 65303, 69122 Issued by Water Resources
01-171-03 Parcel No.
Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Measured static water level at 14' and depth of well at 231'. Installed 2" tremme pipe to 225' and pumped in 9 cubic yards of 8 sack sand mix cement from the bottom of the well to 20'. We then pumped in neat cement from 20' to 15'. Cement was left down 5' from surface for the new water line installation. (original log attached)				
plugging of log 8764				

Date started 5/16/2007 , 19__
Date completed 5/16/2007 , 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

STATE ENGINEERS OFFICE
2007 JUN -5 AM 10:43
RECEIVED

8. WELL CONSTRUCTION
Depth Drilled 232' Feet Depth Cased 232" Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
14"		.250"	0+	232'

Perforations:
Type perforation louvered
Size perforation 3/32 x2"
From 112' feet to 232' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 232'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 14' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Carson Pump Contractor
Address P.O. Box 30159 Contractor
Carson City, MN. 89721
Nevada contractor's license number issued by the State Contractor's Board 39920
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1482
Signed [signature] By driller performing actual drilling on-site or contractor
Date 6/4/2007

USE ADDITIONAL SHEETS IF NECESSARY