REPORT NO. A07.34

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

LOG NO. 103694
PERMIT NO.
BASIN Ø88

NOTICE OF INTENT NO. 59516

1. OWNER Doug Moreau c/o Corbett Construction
MAILING ADDRESS 325 Harbour Cove-Ste #111 Sparks NV 89434
ADDRESS OF WELL 4365 Drake Way
Carson City, NV 89702

2. WELL LOCATION NE 1/4 NE 1/4 SEC. 5 T 17 R 20 E Washoe COUNTY
PERMIT NO ____ PARCEL NO 050-434-04 SUBDIVISION NAME ____

3. TYPE OF WORK
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Plug [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Mud

6. LITHOLOGIC LOG

MATERIAL	STRATA	FROM	TO	THICKNESS
Red, Yellow D.G. Yellow Brwn Clay		0	15	15
Sands, Gravels, Yellow Clay		15	30	15
Firm D.G., Traces Of Yellow Clay		30	35	5
Hard Granule Blue Green Traces		35		
Yellow Clay		35	45	10
Black, White Granite, Green Clay		45	65	20
Thick Green, Yellow, Reddish Clay		65		
S.P. Granite		65	90	25
Gray, Whie Granite, White Clay		90	105	15
Blue, Grn Granite-White Blue Clay		105	150	45
Fractured Blue Green		150	180	30
Hard Blue Grn Granite White Clay		180	220	40
Lt Blue Grn Granite Some Fract	X	220	286	66

RECEIVED 2007 MAY -2 AM 10:45 STATE ENGINEER'S OFFICE

Notes : WGS-84 GPS: Latitude: N39 17.207 Longitude: W119 45.127
N 39.286888
W 119.751116 NAD27

Date Started 04/11/2007 Date Completed 04/19/2007

7. WELL TEST DATA

TEST METHOD [ ] Bailer [ ] Pump [X] Air Develop

	GPM	DRAWDOWN	TIME (HRS)
	20+		2.5

8. WELL CONSTRUCTION
Depth Drilled 286' Depth Cased 286'

HOLE DIAMETER (BIT SIZE)
10 5/8 Inches 0 Feet 100 Feet
8 1/2 Inches 100 Feet 286 Feet
____ Inches ____ Feet ____ Feet

CASING SCHEDULE

Size OD	Weight/Ft	Wall Thickness	From	To
6 5/8"	12.92	.188	+3'	286'

PERFORATIONS:
Type Perforation Factory Size Perforation 3/32 x 3
From 226 Feet to 266 Feet
From ____ Feet to ____ Feet
From ____ Feet to ____ Feet

SURFACE SEAL: [X] Yes [ ] No
Seal Depth 100'
PLACEMENT METHOD: [X] Pumped [ ] Poured
SEAL TYPE: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout [ ] Bentonite

GRAVEL PACKED: [X] Yes [ ] No
From 100 Feet to 286 Feet

9. WATER LEVEL
Static Water Level 120 Feet Below Land Surface
Artesian Flow ____ GPM ____ PSI
Water Temperature Cool F Quality Clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of m knowledge.
Name Aqua Drilling & Well Service, Inc
Address 675 Edison Way
Reno, NV 89502
NV. CONTRACTOR'S LIC. NO 15291 DRILLER'S LIC. NO. ON SITE 2189
Signed Roger Mitchell
By driller performing actual drilling on site or contractor
Dated April 26 - 2007